

San Joaquin Valley Pulmonary
5801 Truxtun Ave
Bakersfield Ca 93309

#05-1-19504

Klassen Corporation
2021 Westwind Drive
Bakersfield, CA 93301

ADDENDUM NUMBER 02

September 10, 2019

NOTICE TO CONTRACTORS FIGURING THIS WORK

| | | |
|-----------|--------|---------------------------------------------------------------------|
| BID DATE: | Date: | September 11, 2019 |
| | Time: | 2:00 PM |
| | Place: | Klassen Corporation 2021 Westwind Drive Bakersfield, CA 93301 |

You are hereby notified of the following additions and/or changes in the Plans and Specifications, which shall take precedence over anything contrary therein. Clarifications, revisions and additions are categorized under date headings based upon Pre-Bid Requests for Information received.

Item 1: Please note bid date change:

- a. **CHANGE:** Bid date extended to September 11, 2019 at 2:00pm, as noted above.

Item 2: Refer to Electrical Plans:

- a. **CLARIFICATION:** Fire Alarm scope to be true design-build. Contractor to provide fire alarm shop drawings as required by City of Bakersfield for approval. The installation of the new fire alarm system to tie into the existing fire alarm panel as identified within Addendum #01.

Item 3: Refer to Finish Plan sheet A7.01 & Detail 19/Sheet A9.02:

- a. **CLARIFICATION:** The outside walls of the Reception and Nurses station to be painted gyp. Board; it is not a plastic laminate face.
- b. **CLARIFICATION:** Restrooms #112 & #115 counters are existing to remain. No work to occur to the finishes within the existing restrooms.
- c. **CLARIFICATION:** As mentioned within addendum #01, reception area to be solid surface, BOTH upper and lower. This is the only room to receive solid surface counters.

END OF ADDENDA 1


Edgar L. Childres

Project Architect

9/6/19
Date