

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 3 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

1st Indoor Fans: Check envelope and mechanical

2nd Indoor Lighting: Check lighting

3rd Heat Rejection: Check envelope and mechanical

4th Pumps & Misc: Check mechanical

5th Domestic Hot Water: Check mechanical

6th Space Heating: Check envelope and mechanical

7th Space Cooling: Check envelope and mechanical

Indoor Fans

Indoor Lighting

Heat Rejection

Pumps & Misc

Domestic Hot Water

Space Heating

Space Cooling

Penalty

Energy Credit

D. EXCEPTIONAL CONDITIONS

This project uses the Simplified Geometry Performance Modeling Approach which is not capable of modeling daylighting controls and assumes the prescriptive Secondary Daylit Control requirements are met. PRESCRIPTIVE COMPLIANCE documentation from NRCC-LT-02-E for the requirements of section 140.6(a) Automatic Daylighting Controls in Secondary Daylit Zones is required. This project includes Domestic Hot Water in the analysis. Please verify that Domestic Hot Water is included in the design for the permitted scope of work.

E. HERS VERIFICATION

This Section Does Not Apply

F. ADDITIONAL REMARKS

None Provided

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 3 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

1. Project Location (city)

2. CA Zip Code

3. Climate Zone

4. Total Conditioned Floor Area in Scope

5. Total Unconditioned Floor Area

6. Total # of Stories (Excludes Above Grade)

7. Total # of dwelling units

specify

13

0 ft²

1

0

8. Standards Version

9. Compliance Software (version)

10. Weather File

11. Building Orientation (deg)

12. Permitted Scope of Work

13. Building Type(s)

14. Site Type

CompliancePro 7.2

BAKERSFIELD_723840_CZ2010.rpw

NI 0 deg

NewComplete

Nonresidential

NaturalGas

B. COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual TDV Energy Use, kWh/ft²-yr)

\$ 140.1

1. Energy Component

2. Standard Design (TDV)

3. Proposed Design (TDV)

4. Compliance Margin (TDV)

5. Percent Better than Standard

Space Heating

6.65

19.37

-12.7%

-22.3%

Space Cooling

97.28

111.59

-13.5%

-14.3%

Indoor Fans

100.76

37.51

63.25

62.8%

Pumps & Misc

--

--

--

--

Heat Rejection

--

--

--

--

Domestic Hot Water

2.96

7.60

-4.44

-150.0%

Indoor Lighting

41.60

37.04

4.56

11.0%

COMPLIANCE TOTAL

251.29

212.37

38.88

15.5%

Receptacles

107.64

107.64

0.0

0.0%

Process

--

--

--

--

Other Litg

--

--

--

--

Process Motors

--

--

--

--

TOTAL

358.89

320.03

38.9

10.8%

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 3 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

G. COMPLIANCE PATH & CERTIFICATE OF COMPLIANCE SUMMARY

Identify which building components use the performance or prescriptive path for compliance. "NA" = not in project
For components that utilize the performance path, indicate the sheet number that includes mandatory notes or plans.

Building Component

Compliance Path

Compliance Forms (required for submittal)

Location of Mandatory Notes on Plans

Envelope

Performance

Prescriptive

NA

NRCC-PRF-ENV-DETAILS (section of the NRCC-PRF-01-E)

NRCC-ENV-01 / 02 / 03 / 04 / 05 / 06-E

NA

Mechanical

Performance

Prescriptive

NA

NRCC-PRF-MCH-DETAILS (section of the NRCC-PRF-01-E)

NRCC-MCH-01 / 02 / 03 / 04 / 05 / 06 / 07-E

NA

Domestic Hot Water

Performance

Prescriptive

NA

NRCC-PRF-PUB-DETAILS (section of the NRCC-PRF-01-E)

NRCC-PLB-01-E

NA

Lighting (Indoor Conditioned)

Performance

Prescriptive

NA

NRCC-LT-01 / 02 / 03 / 04 / 05 (section of the NRCC-PRF-01-E)

NRCC-LT-01 / 02 / 03 / 04 / 05-E

NA

Covered Process: Commercial Kitchens

Performance

Prescriptive

NA

S2 (section of the NRCC-PRF-01-E)

NRCC-PRC-02 / 03-E

NA

Covered Process: Computer Rooms

Performance

Prescriptive

NA

S3 (section of the NRCC-PRF-01-E)

NRCC-PRC-02 / 04-E

NA

Covered Process: Laboratory Exhaust

Performance

Prescriptive

NA

S4 (section of the NRCC-PRF-01-E)

NRCC-PRC-02 / 09-E

NA

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 4 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

G. COMPLIANCE PATH & CERTIFICATE OF COMPLIANCE SUMMARY

The following building components are only eligible for prescriptive compliance. Indicate which are relevant to the project.

Yes

NA

Prescriptive Requirement

Compliance Forms

Yes

NA

Mandatory Requirement

Compliance Forms

☐

☒

Lighting (Indoor Unconditioned) \$140.6

NRCC-LT-01 / 02 / 03 / 04 / 05-E

☐

☒

Commissuring: \$120.8

Simple Systems

NRCC-COR-01 / 02 / 03 / 05-E

NRCC-COR-01 / 02 / 04 / 05-E

☐

☒

Lighting (Outdoor) \$140.7

NRCC-LT-01 / 02 / 03-E

☐

☒

Electrical: \$130.5

Solar Ready: \$110.10

NRCC-SKA-01 / 02-E

NRCC-SKA-01 / 02-E

☐

☒

Lighting (Sign) \$140.8

NRCC-LT-01-E

☐

☒

Covered Process: \$120.6

Parking Garage

NRCC-PRC-05-E

NRCC-PRC-05 / 08-E

NRCC-PRC-10-E

NRCC-PRC-11-E

☐

☒

Solar Thermal Water Heating: \$140.5

NRCC-STH-01-E

☐

☒

Covered Process: \$120.6

Commercial Refrigeration

NRCC-PRC-05-E

NRCC-PRC-05 / 08-E

NRCC-PRC-10-E

NRCC-PRC-11-E

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 5 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

H. CERTIFICATE OF INSTALLATION, CERTIFICATE OF ACCEPTANCE & CERTIFICATE OF VERIFICATION SUMMARY (NRCC/NRCA/NRVC) --

Documentation Author to indicate which Certificates must be submitted for the features to be recognized for compliance (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify). See Tables G, and H, in MCH and UT Details Sections for Acceptance Tests and forms by equipment.

Building Component

Compliance Forms (required for submittal)

Pass

Fail

Envelope

☒

☐

NRCC-ENV-01-E - For all buildings

☐

☐

☒

☐

NRCA-ENV-02-F - NRCC label verification for fenestration

☐

☐

☒

☐

NRCA-MCH-02-A- Outdoor Air

☐

☐

☒

☐

NRCA-MCH-03-A - Constant Volume Single Zone HVAC

☐☐

☒

☐

NRCA-MCH-04-H - Air Distribution Duct Leakage

☐☐

☒

☐

NRCA-MCH-05-A - Air Economizer Controls

☐☐

☒

☐

NRCA-MCH-06-A - Demand Control Ventilation

☐☐

☒

☐

NRCA-MCH-07-A - Supply Fan Variable Flow Controls

☐☐

☒

☐

NRCA-MCH-08-A - Valve Leakage Test

☐☐

☒

☐

NRCA-MCH-09-A - Supply Water Temp Reset Controls

☐☐

☒

☐

NRCA-MCH-10-A - Hydronic System Variable Flow Controls

☐☐

☒

☐

NRCA-MCH-11-A - Auto Demand Shed Controls

☐☐

☒

☐

NRCA-MCH-12-A - Packaged Direct Expansion Units

☐☐

☒

☐

NRCA-MCH-13-A - Air Handling Units and Zone Terminal Units

☐☐

☒

☐

NRCA-MCH-14-A - Distributed Energy Storage

☐☐

☒

☐

NRCA-MCH-15-A - Thermal Energy Storage

☐☐

☒

☐

NRCA-MCH-16-A - Supply Air Temp Reset Controls

☐☐

☒

☐

NRCA-MCH-17-A - Condensate Water Temp Reset Controls

☐☐

☒

☐

NRCA-MCH-18-A - Energy Management Controls Systems

☐☐

☒

☐

NRVC-MCH-04-H - Duct Leakage Test

☐☐

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 6 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

I. CERTIFICATE OF INSTALLATION, CERTIFICATE OF ACCEPTANCE & CERTIFICATE OF VERIFICATION SUMMARY (NRCC/NRCA/NRVC) --

Documentation Author to indicate which Certificates must be submitted for the features to be recognized for compliance (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify). See Tables G, and H, in MCH and UT Details Sections for Acceptance Tests and forms by equipment.

Building Component

Compliance Forms (required for submittal)

Pass

Fail

Plumbing

☒

☐

NRCC-PLB-01-E - For all buildings with Plumbing Systems

☐

☐

☒

☐

NRCC-PLB-02-E - required on central systems in high-rise residential, hotel/motel application.

☐

☐

☒

☐

NRCC-PLB-03-E - Single dwelling unit systems in high-rise residential, hotel/motel application.

☐

☐

☒

☐

NRCC-PLB-03-E - HERS verified central systems in high-rise residential, hotel/motel application.

☐☐

☒

☐

NRCC-PLB-03-E - HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.

☐☐

☒

☐

NRCC-PLB-03-E - HERS verified central systems in high-rise residential, hotel/motel application.

☐☐

☒

☐

NRCC-PLB-03-E - HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.

☐☐

☒

☐

NRCC-PLB-03-E - Any solar water heating

☐☐

☒

☐

NRCC-LT-01-E - For all buildings

☐☐

☒

☐

NRCC-LT-02-E - Lighting control system, or for an Energy Management Control System (EMCS)

☐☐

☒

☐

NRCC-LT-03-E - Line voltage track lighting integral current limiter, or for a supplementary overcurrent protection panel used to energize only line-voltage track lighting

☐☐

☒

☐

NRCC-LT-04-E - Two interlocked systems serving an auditorium, a conference room, a conference room, or a theater

☐☐

☒

☐

NRCC-LT-05-E - Lighting Control Credit Power Adjustment Factor (PAC)

☐☐

☒

☐

NRCC-LT-06-E - Additional wattage installed in a video conferencing studio

☐☐

☒

☐

NRCA-LT-02-A - Occupancy sensors and automatic time switch controls

☐☐

☒

☐

NRCA-LT-03-A - Automatic daylighting controls

☐☐

☒

☐

NRCA-LT-04-A - Demand responsive lighting controls

☐☐

☒

☐

NRCC-LT-01-E - Outdoor Lighting

☐☐

☒

☐

NRCC-LT-02-E - EMCS Lighting Control System

☐☐

☒

☐

NRCC-LT-02-A - Outdoor Lighting Control

☐☐

☒

☐

NRCC-LT-03-E - Sign Lighting

☐☐

☒

☐

NRCA-LT-01-E - Electrical Power Distribution

☐☐

☒

☐

NRCC-SPV-01-E Photovoltaic Systems

☐☐

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 7 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

J. CERTIFICATE OF INSTALLATION, CERTIFICATE OF ACCEPTANCE & CERTIFICATE OF VERIFICATION SUMMARY (NRCC/NRCA/NRVC) --

Documentation Author to indicate which Certificates must be submitted for the features to be recognized for compliance (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify). See Tables G, and H, in MCH and UT Details Sections for Acceptance Tests and forms by equipment.

Building Component

Compliance Forms (required for submittal)

Pass

Fail

Covered Process

☒

☐

NRCC-PRC-01-E Covered Process

☐

☐

☒

☐

NRCA-PRC-01-F - Compressed Air Systems

☐

☐

☒

☐

NRCA-PRC-02-F - Kitchen Exhaust

☐

☐

☒

☐

NRCA-PRC-03-F - Garage Exhaust

☐☐

☒

☐

NRCA-PRC-04-F - Refrigerated Warehouse- Evaporator Fan Motor Controls

☐☐

☒

☐

NRCA-PRC-05-F - Refrigerated Warehouse- Evaporative Condenser Controls

☐☐

☒

☐

NRCA-PRC-06-F - Refrigerated Warehouse- Air Cooled Condenser Controls

☐☐

☒

☐

NRCA-PRC-07-F - Refrigerated Warehouse- Variable Speed Compressor

☐☐

☒

☐

NRCA-PRC-08-F - Electrical Resistance Underlath Heating System

☐☐

L. ENVELOPE GENERAL INFORMATION (See NRCC-PRF-ENV-DETAILS for more information)

1. Total Conditioned Floor Area

2. Total Unconditioned Floor Area

3. Addition Conditioned Floor Area

4. Addition Unconditioned Floor Area

5. Total Gross Surface Area

6. Total Fenestration Area

7. Window to Wall Ratio

6,695 ft²

0 ft²

0 ft²

0 ft²

6,695 ft²

2,230 ft²

71.3%

1

0

0

0

6,695

2,230

71.3%

1. Total Conditioned Floor Area

2. Total Unconditioned Floor Area

3. Addition Conditioned Floor Area

4. Addition Unconditioned Floor Area

5. Total Gross Surface Area

6. Total Fenestration Area

7. Window to Wall Ratio

6,695 ft²

0 ft²

0 ft²

0 ft²

6,695 ft²

2,230 ft²

71.3%

1

0

0

0

6,695

2,230

71.3%

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 8 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

K. FENESTRATION ASSEMBLY SUMMARY

1. Fenestration Assembly Name / Tag or ID

2. Fenestration Type / Product Type

3. Certification Method¹

4. Assembly Method

5. Area ft²

6. Overall U-factor

7. Overall SHGC

8. Overall VT

9. U-factor

10. SHGC

11. VT

Double Metal Clear

Vertical Fenestration

Field Window

Default Performance

Steeltite

2310

0.71

0.60

0.77

N

☐

☐

Residential Prescriptive

Vertical Fenestration

Field Window

NFRC Rated

Manufactured

1750

0.32

0.25

0.50

N

☐

☐

L. OPAQUE SURFACE ASSEMBLY SUMMARY

1. Surface Name

2. Surface Type

3. Area (ft²)

4. Framing Type

5. Cavity R-Value

6. Continuous R-Value

7. U-Factor / F-Factor / C-Factor

8. U-factor

9. SHGC

10. VT

R-19 Wall/9

ExteriorWall

5270

Wood

19

NA

U-Factor: 0.072

0.072

N

☐

☐

Slab On Grade/18

UndergroundFloor

6695

NA

0

NA

F-Factor: 0.790

0.790

N

☐

☐

R-30 Roof Attic/20

Roof

6695

Wood

30

NA

U-Factor: 0.038

0.038

N

☐

☐

M. ROOFING PRODUCT SUMMARY

1. Product Type

2. Product Density (lb/ft³)

3. Age² Solar Reflectance

4. Thermal Emittance

5. SRI

6. Cool Roof Credit³

7. Roofing Product Description

8. U-factor

9. SHGC

10. VT

R-30 Roof Attic/20

5.85

0.08

0.75

NA

No

NA

0

☐

☐

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E
Page 9 of 22
Calculation Date/Time: 22-38, Sun, Aug 11, 2019
Input File Name: c19-148.cbdt6x

M. HVAC SYSTEM SUMMARY (See NRCC-PRF-MCH-DETAILS for more information)

\$ 110.1 / \$ 110.2

1. Equip Name

2. Equip Type

3. System Type (Simple "T" or Complex "T")

4. Qty

5. Total Heating Output (Btu/hr)

6. Total Cooling Output (Btu/hr)

7. Supply Heat Source (V/N)

8. Total Cooling Output (Btu/hr)

9. Efficiency

10. Acceptance Testing Required? (Y/N)

11. Status

12. Pass

13. Fail

5 TON RTU AC.17

SZAC

(Packaged3Phase)

Simple

2

80

No

0

58

SER-14.00 / EER-12.20

AFUE-82.0

No

N

☐

☐

3 TON RTU AC.56810

SZAC

(Packaged3Phase)

Simple

4

80

No

0

35

SER-14.00 / EER-12.20

AFUE-82.0

Yes

N

☐

☐

7.5 TON RTU AC.234

SZAC

(Packaged3Phase)

Simple

1

100

No

0

86

EER-12.2

AFUE-82.0

Yes

N

☐

☐

3 RTU

SZAC

(Packaged3Phase)

Simple

1

80

No

0

35

SER-14.00 / EER-12.20

AFUE-82.0

Yes

N

☐

☐

IT ROOM MINI SPLIT

SZHP (CRAC)

Simple

1

9

No

0

9

SER-14.00 / EER-12.20

HPF-14.00

Yes

N

☐

☐

N. ECONOMIC & FAN SYSTEMS SUMMARY¹

\$ 140.4

1. Equip Name

2. Outside Air

3. Supply Fan

4. Return Fan

5. Economizer Type (if present)

6. Pass

7. Fail

5 TON RTU AC.17

CTM

CTM

HP

BHP

TSP (Btu/h WC)

Control

CTM

HP

BHP

TSP (Btu/h WC)

Control

NoEconomizer

☐

☐

3 TON RTU AC.56810

84

1200

0.200

0.200

0.53

ConstantVolume

NA

NA

NA

NA

NA

NoEconomizer

☐

☐

7.5 TON RTU AC.234

182

3000

0.310

0.310

0.39

ConstantVolume

NA

NA

NA

NA

NA

NoEconomizer

☐

☐

3 RTU

185

1200

0.200

0.200

0.53

ConstantVolume

NA

NA

NA

NA

NA

NoEconomizer

☐

☐

IT ROOM MINI SPLIT

10

300

0.180

0.180

1.90

ConstantVolume

NA

NA

NA

NA

NA

NoEconomizer

☐

☐

O. EQUIPMENT CONTROLS

\$ 120.2

1. Equip Name

2. Equip Type

3. Controls

4. Pass

5. Fail

5 TON RTU AC.17

SZAC

No DDC Controls
No Economizer
No Supply Air Temp. Control
No Optimum Start
No Exhaustive Cooler
No Heat Recovery

☐

☐

3 TON RTU AC.56810

SZAC

No DDC Controls
No Economizer
No Supply Air Temp. Control
No Optimum Start
No Exhaustive Cooler
No Heat Recovery

☐

☐

CA Building Energy Efficiency Standards- 2016 Nonresidential Compliance Report Version: NRCC-PRF-01-E-08022018-5160 Report Generated at: 2019-08-11 22:38:42

Project Name: SAN JOAQUIN PULMONARY
Project Address: 22-38, Sun, Aug 11, 2019
Compliance Scope: NewComplete

NRCC-PRF-01-E

