


THE USE OF THESE PLANS AND SPECIFICATIONS SHALL BE RESTRICTED TO THE ORIGINAL SITE FOR WHICH THEY WERE PREPARED AND PUBLICATION THEREOF IS EXPRESSLY LIMITED TO SUCH USE. RE-USE, REPRODUCTION, OR REPLICATION BY ANY METHOD, IN WHOLE OR IN PART, IS PROHIBITED. TITLE TO THE PLANS AND SPECIFICATIONS REMAINS WITH THE ENGINEER WITHOUT RESERVE. USUAL CONTACT WITH THESE PLANS AND SPECIFICATIONS SHALL CONSTITUTE FORMAL ADOPTION OF THE ACCEPTANCE OF THESE RESTRICTIONS. CANTelmi ENGINEERING

NOTHING IN THE DRAWINGS AND/OR SPECIFICATIONS SHALL BE CONSTRUED TO PERMIT AN INSTALLATION IN VIOLATION OF APPLICABLE CODES AND/OR RESTRICTIONS. SHOULD ANY CHANGE IN THE DRAWINGS AND/OR SPECIFICATIONS BE NECESSARY IN ORDER TO COMPLY WITH APPLICABLE CODES AND/OR REQUIREMENTS, THE CONTRACTOR SHALL NOTIFY ENGINEER OF RECORD. THE WORK PERFORMED UNDER THIS CONTRACT SHALL BE IN FULL ACCORDANCE WITH THE LATEST CODES, REGULATIONS, RESTRICTIONS AND REQUIREMENTS. CONTRACTOR TO OBTAIN CLARIFICATION FROM ENGINEER OF RECORD WHERE CONFLICTS IN DRAWING OR DIMENSIONS ARISE PRIOR TO PROCEEDING WITH CONSTRUCTION.

LIGHT FIXTURE SCHEDULE				VOLTAGE: 120V (U.O.N.)
TYPE	INPUT WATTS	DESCRIPTION AND MANUFACTURER		REMARKS
F1	51	2X4 LED VOLTAGE: UNV LAMP: LED MANUFACTURER: COLUMBIA#LIT-24-40-HL-SM-FS-A12-ED-U-FK24		FLANG KIT FOR SURFACE MT FIXTURE F1E INDICATES 90MIN BATTERY ELL14
F2	48	1X4 LED VOLTAGE: UNV LAMP: LED MANUFACTURER: COLUMBIA#LAW-		-
F3	26	CAN LIGHT VOLTAGE: UNV LAMP: LED MANUFACTURER: PRESCOLITE#LF8SL-DM1-8LFSL-20L-40K-9CRI-		-
F4	29	WALL PACK VOLTAGE: UNV LAMP: LED MANUFACTURER: HUBBELL#LNC2-12L-U-4K-3		-
F5E	8	EM OUTDOOR LIGHT VOLTAGE: UNV LAMP: LED MANUFACTURER: DUAL LITE#PG		-
F6	150	HIGH BAY LIGHT VOLTAGE: UNV LAMP: LED MANUFACTURER: COLUMBIA#PEL-4-50-MHHE-FA-W-ED		-
X1	8	EXIT LIGHT WITH EM LIGHTS VOLTAGE: UNV LAMP: LED MANUFACTURER: COMPASS#CCR		-
X2	8	EXIT LIGHT WITH EM LIGHTS VOLTAGE: UNV LAMP: LED MANUFACTURER: DUAL LITE#		-
F7	-	EXTERIOR POLE LIGHT VOLTAGE: UNV LAMP: LED MANUFACTURER: KIM #ERA-ACORN, GREEN HUNTER COLOR TWIN # 2B/AE213120S3K120, SINGLE KIM #1A/AE213120S3K120		-
F8	51	SUSPENDED LIGHT FIXTURE VOLTAGE: UNV LAMP: LED MANUFACTURER: EATON # 4WSL-4-LD2-SPS-EL14W-LV1-L840		-

1 SINGLE LINE DIAGRAM

FEEDER SCHEDULE					
NUMBER	AMPS	CONDUIT	CONDUCTORS PER CONDUIT (THHN/THWN. CU)		
		PVC. EMT OR GRS	3Ø 4W (C)	PULL LINE (E)	(THHN/THWN) COPPER
01	40	3/4"	4 #8	1	#10
02	50	3/4"	4 #6	1	#10
03	60	1"	4 #6	1	#10
04	70	1-1/2"	4 #4	1	#8
05	80	1-1/2"	4 #4	1	#8
06	90	1-1/2"	4 #2	1	#6
07	100	1-1/2"	4 #2	1	#6
08	110	1-1/2"	4 #1	1	#6
09	125	1-1/2"	4 #1	1	#6
10	150	2"	4 #1/0	1	#6
11	175	2"	4 #2/0	1	#4
12	200	2"	4 #3/0	1	#4
13	400	(2)2"	4 #3/0	1	#2 EACH



CANTELM ENGINEERING
ELECTRICAL / ELECTRICAL
2130 F STREET BAKERSFIELD, CA 93301
TEL: (661) 324-5252 FAX: (661) 324-8439 Cantelmi@cantelmi.net

SINGLE LINE DIAGRAM
MICHAEL FLOORING, INC.
6500 DISTRICT BLVD.
BAKERSFIELD, CA 93313

DATE	ISSUED

DATE	MARK	ISSUED

DWG. BY	DBC
CHKD BY	KM
DATE	12-21-18
JOB NO.	C18-135
FILE NO.	



SHEET
E9.0
SHEET