ADDENDUM 1

PROJECT: East Travel Plaza

Wheeler Ridge, CA

DATE: September 17, 2019 BID DATE: September 25, 2019

You are advised to make the following additions, deletions, and or corrections to the Contract Documents. This Addendum shall become part of the contract documents. All remaining portions of the Contract Documents shall remain in full force and effect.

CONSTRUCTION DOCUMENT CLARIFICATIONS

Item Description

110111	Description	
1	Project Manual Provided	
2	Bid Schedule of Values Spreadsheet Provided	
3	Sheet J-EQ2.1 – KES refers to 'Kitchen Equipment Supplier'. PSP refers to Graphics Vendor	
4	For Owner supplied equipment, the GC is responsible to receive, unload and store as necessary until	
	installation	
5	HVAC – reference only – MUA is interlocked with HVAC system, (construction set will include revised text)	
6		

CHANGES TO DRAWINGS

Sheet # Item Description

Giloct II	100111	Boomption
M4.01		There are five 8" supply diffusers over BOH showing 310 CFM. These will be increased to 10" diffusers in order to accommodate air flow. Construction set sheet will be clouded & updated

End of ADDENDUM 1

J D Satterwhite	September 17, 2019
Issued By	Date