

## GENERAL NOTES

## COMMUNICATION PLAN NOTES

## FIRE SPRINKLER AND ALARM SYSTEMS NOTES

(DEFERRED APPROVAL)

- CODE COMPLIANCE: ALL WORK SHALL CONFORM TO AND BE PERFORMED IN ACCORDANCE WITH CODES, STANDARDS, AND ORDINANCES AS SET FORTH BY THE AUTHORITIES HAVING JURISDICTION AND THEIR LATEST ADOPTED EDITIONS (IN EFFECT AT TIME OF BUILDING PERMIT APPLICATION) OF THE FOLLOWING PUBLICATIONS:
  - CALIFORNIA CODE OF REGULATIONS TITLE 24; INCLUDES 2016 CALIFORNIA ELECTRICAL CODE, 2016 CALIFORNIA FIRE CODE, 2016 CALIFORNIA BUILDING CODE, ETC. WITH LOCAL AMENDMENTS AS APPLICABLE.
  - AMERICANS WITH DISABILITIES ACT (ADA).
- SAFETY: THE ELECTRICAL CONTRACTOR IS RESPONSIBLE TO MAINTAIN ALL EQUIPMENT IN A SAFE AND RESPONSIBLE MANNER. KEEP DEAD FRONT EQUIPMENT IN PLACE WHILE EQUIPMENT IS ENERGIZED. CONDUCT ALL CONSTRUCTION OPERATIONS IN A SAFE MANNER FOR EMPLOYEES AS WELL AS OTHER WORKPERSONS OR ANYONE VISITING THE JOB SITE. PROVIDE BARRIERS, FLAGS, TAPE, ETC. AS REQUIRED FOR SAFETY. THE CONTRACTOR SHALL HOLD ALL PARTIES HARMLESS OF NEGLIGENT SAFETY PRACTICES, WHICH MAY CAUSE INJURY TO OTHERS ON OR NEAR THE JOB SITE.
- FIRE RATED ASSEMBLIES SHALL MAINTAIN RATINGS AS SPECIFIED IN THE CALIFORNIA BUILDING CODE CHAPTER 7. CONTRACTOR SHALL PROVIDE AND INSTALL PHYSICAL ENCLOSURE AROUND FIXTURES, PANELS, ETC. AS REQUIRED. ALL ASSEMBLIES TO BE PENETRATED SHALL BE INSTALLED WITH APPLICABLE THROUGH-PENETRATION FIRESTOP SYSTEM AS DETERMINED BY UL CLASSIFICATION. BEFORE CONSTRUCTION, VERIFY AND COMPLY WITH REQUIREMENTS OF LOCAL AUTHORITY HAVING JURISDICTION.
- MOUNTING HEIGHTS SHALL BE AS FOLLOWS UNLESS OTHERWISE NOTED:
  - +15" AFF: RECEPTACLES, TELEPHONE, TV & DATA OUTLETS. (MEASURED BOTTOM OF OUTLET BOX)
  - +46" AFF: OUTLET ABOVE COUNTER (MEASURED TOP OF OUTLET BOX)
  - +48" AFF: LIGHT SWITCHES. (MEASURED TOP OF OUTLET BOX)
  - +48" AFF: FIRE ALARM MANUAL PULL STATIONS, T-STATS. (MEASURED TOP OF OUTLET BOX)
  - THE LOWER OF +80" AFF TO BOTTOM OF LENS, OR 6" BELOW CEILING: FIRE ALARM VISUALS.

CALIFORNIA BUILDING CODE 1136A ELECTRICAL RECEPTACLE, SWITCH AND CONTROL HEIGHTS:  
 [1136A.1] RECEPTACLE HEIGHTS: ELECTRICAL RECEPTACLE OUTLETS ON BRANCH CIRCUITS OF 30 AMPERES OR LESS AND COMMUNICATION SYSTEM RECEPTACLES SHALL BE LOCATED NO MORE THAN 48 INCHES FROM THE TOP OF THE RECEPTACLE OUTLET BOX NOR LESS THAN 15 INCHES MEASURED FROM THE BOTTOM OF THE RECEPTACLE OUTLET BOX TO THE LEVEL OF THE FINISH FLOOR OR WORKING PLATFORM. IF THE REACH IS OVER A PHYSICAL BARRIER OR AN OBSTRUCTION (FOR EXAMPLE, A KITCHEN BASE CABINET), RECEPTACLES SHALL BE LOCATED WITHIN THE REACH SPECIFIED IN SECTION 118A.3. PHYSICAL BARRIERS AND OBSTRUCTIONS SHALL NOT EXTEND MORE THAN 25 INCHES FROM THE WALL BENEATH THE RECEPTACLE.

RECEPTACLE OUTLETS THAT DO NOT SATISFY THESE SPECIFICATIONS ARE ACCEPTABLE PROVIDED THAT COMPARABLE RECEPTACLES OUTLETS, THAT PERFORM THE SAME FUNCTIONS, ARE PROVIDED WITHIN THE SAME AREA AND ARE ACCESSIBLE. EXCEPTIONS:

  - RECEPTACLE OUTLETS INSTALLED AS PART OF PERMANENTLY INSTALLED BASEBOARD HEATERS ARE EXEMPT
  - REQUIRED RECEPTACLE OUTLETS SHALL BE PERMITTED IN FLOORS WHEN ADJACENT TO SLIDING PANELS OR WALLS.
  - BASEBOARD ELECTRICAL OUTLETS USED IN A RELOCATABLE PARTITIONS, WINDOW WALLS OR OTHER ELECTRICAL CONVENIENCE FLOOR OUTLETS ARE NOT SUBJECT TO THE MINIMUM HEIGHT REQUIREMENTS.
- THIS SECTION SHALL NOT APPLY TO EXISTING BUILDINGS WHEN THE ENFORCING AGENCY DETERMINES THAT COMPLIANCE WITH THESE STANDARDS WOULD CREATE AN UNREASONABLE HARSHIP.
 

[1136A.2] SWITCH AND CONTROL HEIGHTS: CONTROLS OR SWITCHES INTENDED TO BE USED BY THE OCCUPANT OF THE ROOM OR AREA TO CONTROL LIGHTING AND RECEPTACLE OUTLETS, APPLIANCES, ALARMS OR COOLING, HEATING AND VENTILATING EQUIPMENT SHALL BE LOCATED NO MORE THAN 48 INCHES MEASURED FROM THE TOP OF THE OUTLET BOX OR NOR LESS THAN 15 INCHES MEASURED FROM THE BOTTOM OF THE OUTLET BOX TO THE LEVEL OF THE FINISHED FLOOR OR WORKING PLATFORM. IF THE REACH IS OVER A PHYSICAL BARRIER OR AN OBSTRUCTION (FOR EXAMPLE, A KITCHEN BASE CABINET) SWITCHES AND CONTROLS SHALL BE LOCATED WITHIN THE REACH RANGES SPECIFIED IN SECTION 1136A.3. PHYSICAL BARRIERS OR OBSTRUCTIONS SHALL NOT EXTEND MORE THAN 25 INCHES FROM THE WALL BENEATH A CONTROL.

SWITCHES AND CONTROLS THAT DO NOT SATISFY THESE SPECIFICATIONS ARE ACCEPTABLE PROVIDED THAT COMPARABLE CONTROLS OR OUTLETS, THAT PERFORM THE SAME FUNCTIONS, ARE PROVIDED WITHIN THE SAME AREA AND ARE ACCESSIBLE. EXCEPTIONS:

APPLIANCES (E.G. KITCHEN STOVES, DISHWASHERS, RANGE HOODS, MICROWAVE OVENS, AND SIMILAR APPLIANCES WHICH HAVE CONTROLS LOCATED ON THE APPLIANCES.

BEFORE ROUGH-IN, VERIFY ALL MOUNTING HEIGHTS AND EXACT LOCATIONS FOR ALL EQUIPMENT ELECTRICAL CONNECTIONS, STUB-UPS, RECEPTACLES, OUTLETS, ETC. WITH ARCHITECT OR OWNER. PLACE DEVICES LOCATED ABOVE COUNTERS, SHELVING, ETC. AND IN BATHROOMS SO AS NOT TO CONFLICT WITH EDGES OF WAINSCOTING, COUNTER SPLASH, SHELVING, ETC. ARCHITECTURAL SHEETS SHALL GOVERN.
- LABEL PANELS, CABINETS, BACKBOARDS, MAIN DEVICES, SAFETY SWITCHES, CONTACTORS AND OTHER SPECIFICALLY DESIGNATED EQUIPMENT SHOWN ON PLANS. USE ENGRAVED LAMINATED PLASTIC NAMEPLATES ATTACHED BY SCREWS OR RIVETS. FOR FEEDERS, NEATLY AND INDELIBLY LABEL CONDUIT DESTINATIONS ON BOTH VISIBLE ENDS OF CONDUIT RUNS WHERE CONDUITS TERMINATE AT DESIGNATED ENCLOSURES, STRUCTURES OR EQUIPMENT (INCLUDING PULL AND SPLICE BOXES).

- BEFORE CONSTRUCTION, COORDINATE AND VERIFY ALL DATA AND TELEPHONE LOCATIONS WITH OWNER OR ARCHITECT.
- DEVICE LOCATIONS SHOWN ARE SCHEMATIC AND APPROXIMATE. EXACT LOCATIONS SHALL BE FIELD VERIFIED DURING ROUGH-IN WITH ARCHITECTURAL ELEVATIONS, CASEWORK SHOP DRAWINGS, FURNITURE, ETC. AND SHALL BE COORDINATED WITH OTHER TRADES TO AVOID CONFLICT WITH OTHER EQUIPMENT.
- ELECTRICAL AND COMMUNICATIONS OUTLETS SHOWN IN THE SAME LOCATION, SHALL BE MOUNTED ON OPPOSITE SIDES OF THE SAME STUD. COORDINATE BETWEEN ELECTRICAL AND COMMUNICATIONS PLANS.

## CONDUIT SYSTEMS NOTES

CONDUIT SYSTEMS USED ON THIS PROJECT SHALL BE AS FOLLOWS

- PVC SCHEDULE 40 OR 80 - underground/below slab with GRS elbows and risers tape wrapped).
- ELECTRICAL METALLIC CONDUIT (EMT) - above grade/slab in building construction and where exposed above 8'-0" aff.
- GALVANIZED RIGID STEEL (GRS) - where exposed below 8'-0" aff. and/or where subject to physical damage.
- FLEXIBLE STEEL CONDUIT - above ceilings and/or concealed in building construction (seal tight flex rquired in exterior locations).
- MC CABLE ALLOWED FOR LIGHTING BRANCH CIRCUIT ABOVE T-BAR CEILING SPACE

REFER TO SECTIONS 16110 & 16120 OF SPECIFICATIONS FOR ADDITIONAL INFORMATION. CONDUITS SHALL BE MINIMUM 1/2" UNLESS OTHERWISE NOTED, 3/4" FOR ALL HOME RUN CONDUITS AND WHERE ROUTED BELOW SLAB OR UNDERGROUND. CONDUIT SIZES, WHERE NOT NOTED ON THE DRAWINGS, SHALL BE SIZED FOR MAXIMUM 40% FILL PER CEC 310-6.

ADDITIONAL CONDUIT REQUIREMENTS.

- PROVIDE WHITE DECORA STYLE OUTLETS WITH WHITE COVER PLATES
- REFER TO ELECTRICAL DETAILS FOR METAL PIPE PENETRATION THRU FIRE RATED WALL. PENETRATION OF FIRE-RESISTIVE WALLS AND FLOOR CEILINGS SHALL BE PROTECTED AS REQUIRED IN CBC SECTION 714.
- REFER TO ELECTRICAL DETAIL FOR DEVICE INSTALLATION FOR FIRE RATED WALLS.
- NO CONDUITS OR PIPING IN ANY SPACE SHALL BE EXPOSED AT THE CEILING AND WALL (COORDINATE WITH ALL DISCIPLINES PRIOR TO CONSTRUCTION).

## MECHANICAL SYSTEMS

- MECHANICAL UNIT CONDUITS: TO PREVENT DAMAGE DUE TO VIBRATION, BOTH POWER AND CONTROL WIRING CONDUITS FEEDING EXTERIOR MECHANICAL UNITS SHALL BE PROVIDED AND INSTALLED BY ELECTRICAL CONTRACTOR WITH LIQUID TIGHT FLEXIBLE TYPE AT FINAL CONNECTION TO UNIT AND BETWEEN ROOF JACK AND DISCONNECT SWITCH WHERE DISCONNECT IS MOUNTED ON UNIT.
- MECHANICAL CONTROLS ROUGH-IN: PROVIDE AND INSTALL J-BOX, RING AND CONDUIT (SIZE ALL AS REQUIRED) FROM EACH MECHANICAL CONTROLS LOCATION TO CONTROLLED MECHANICAL UNITS.
- T-STAT J-BOXES: PROVIDE AND INSTALL 4" SQUARE JUNCTION BOX WITH 1-GANG RING AND 1/2" CONDUIT TO ACCESSIBLE CEILING SPACE ABOVE AT EACH THERMOSTAT LOCATION.
- EXHAUST FANS SHALL BE PROVIDED & INSTALLED BY MECHANICAL CONTRACTOR WITH WIRING CONNECTIONS MADE BY ELECTRICAL CONTRACTOR.
- MECHANICAL EQUIPMENT CONTROLS: MECHANICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL LOW VOLTAGE WIRE AND CONNECTIONS (BELOW 120 VOLT) TO AND FROM ALL MECHANICAL CONTROL DEVICES. ALL LOW VOLTAGE CONTROL WIRE SHALL BE IN CONDUIT, UNLESS OTHERWISE NOTED.
- PULLROPES: ANY RACEWAY WITHOUT CABLE OR WIRE SHALL BE INSTALLED WITH MINIMUM 200 POUND TEST PULL LINE AND LARGER IF REQUIRED BY SERVING UTILITY COMPANY. ANY NEW OR EXISTING COMMUNICATION OR SIGNAL RACEWAY ROUTED BETWEEN BUILDINGS, SIGNAL CABINETS, AND/OR SIGNAL CLOSETS WITH FUTURE CAPACITY SHALL BE INSTALLED WITH MINIMUM 200 POUND TEST PULL LINE AS WELL AS THE CALLED FOR CABLE.
- PROVIDE SEALTITE POWER & CONTROL CONNECTIONS TO ALL AC UNITS.
- ALL EQUIPMENT SHOWN ABOVE ROOF IS NEMA 3R.
- VERIFY EXACT EQUIPMENT LOCATIONS AND POINTS OF CONNECTION WITH MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN.
- FUSE DISCONNECT SWITCHES PER EQUIPMENT NAMEPLATE RATING.

FIRE SPRINKLER MONITORING ALARM SYSTEM IS A DEFERRED APPROVAL AND DEVICES SHOWN ON PLANS ARE FOR REFERENCE ONLY. FULL DESIGN-BUILD SHOP DRAWINGS SHALL BE PREPARED BY THE CONTRACTOR AND BE SUBMITTED TO THE ARCHITECT AND ENGINEER FOR REVIEW, UPON FAVORABLE REVIEW BY THE ARCHITECT AND ENGINEER, SHOP DRAWINGS SHALL BE SUBMITTED BY THE CONTRACTOR TO THE LOCAL FIRE AUTHORITY FOR APPROVAL. INSTALLATION OF THE FIRE ALARM SYSTEM SHALL NOT BEGIN UNTIL THE LOCAL FIRE AUTHORITY HAS APPROVED THE SHOP DRAWINGS

- PROVIDE ALL WORK AND MATERIAL REQUIRED FOR A COMPLETE AND OPERATING FIRE ALARM SYSTEM. WORK SHALL INCLUDE (BUT NOT BE LIMITED TO):
  - SHOP DRAWINGS
  - SUBMITTAL FOR APPROVAL
  - COMPLETE INSTALLATION AND TESTING
  - SYSTEM TRAINING FOR OWNER'S REPRESENTATIVE
  - WARRANTY
- SUBMIT A SEPARATE SET OF DETAILED FIRE ALARM PLANS, SPECIFICATIONS AND ENGINEERING CALCULATIONS INCLUDING BUT NOT NECESSARILY LIMITED TO:
  - CSFM LISTING #'S AND MANUFACTURER MODEL #'S FOR EVERY SYSTEM COMPONENT WHICH IS TO BE INTERCONNECTED AS A PART OF THIS PROJECT.
  - SINGLE LINE, RISER AND POINT TO POINT WIRING DIAGRAMS INCLUDING BATTERY AND VOLTAGE DROP CALCULATIONS FOR THE ENTIRE SYSTEM.
  - INDICATION OF CONDUCTOR TYPE(S), POWER-LIMITED OR NON-POWER-LIMITED SYSTEM.
  - SCALED ELEVATION OF REMOTE GRAPHIC ANNUNCIATOR PANEL AT ENTRY. (IF REQUIRED).
  - LIST OF PROPOSED ZONES FOR ALL INITIATING DEVICES.
  - MATRIX OF SYSTEM OPERATION.
  - INFORMATION AS REQUIRED TO DEMONSTRATE COMPLIANCE WITH APPLICABLE CODE(S) AND GAIN APPROVAL OF AUTHORITY(IES) HAVING JURISDICTION.

FIRE ALARM SYSTEM INSTALLATION SHALL NOT BEGIN UNTIL SEPARATE PERMIT HAS BEEN OBTAINED AND ALL OF THE ABOVE HAS BEEN ACCEPTED AND SIGNED BY THE AUTHORITY(IES) HAVING JURISDICTION AND THE ARCHITECT. AFTER CONSTRUCTION, PROVIDE ACCURATE FIELD RECORD DRAWINGS TO OWNER.
- AS A MINIMUM, UNLESS OTHERWISE NOTED, FIRE ALARM CONTROL PANEL SHALL BE PROVIDED WITH BATTERY BACKUP, 4 ZONES AND 1 SIGNAL CIRCUIT WITH PROVISIONS FOR FUTURE EXPANSION. PROVIDE WITH DIALER (DACT) AND CONNECT TO COMMUNICATIONS SYSTEM WITH (2) DEDICATED VOICE LINES AS REQUIRED TO SEND SEPARATE AND DISTINCT SIGNALS (AS REQUIRED BY THE FIRE DEPARTMENT) TO AN APPROVED CENTRAL STATION. FIRE SPRINKLER RISER WATER FLOW AND / OR VALVE TAMPER SWITCHES SHALL BE PROVIDED AND INSTALLED BY THE SPRINKLER SYSTEM CONTRACTOR, AND WIRED BACK TO THE FACP BY THE FIRE ALARM CONTRACTOR. COORDINATE FOR PROPER VOLTAGE. ALL FIRE ALARM COMPONENTS SHALL BE CALIFORNIA STATE FIRE MARSHAL LISTED.
- DUCT SMOKE DETECTORS SHALL BE PROVIDED BY ELECTRICAL CONTRACTOR AND INSTALLED BY MECHANICAL CONTRACTOR. DETECTOR POWER AND SUPERVISORY WIRING AND CONNECTIONS SHALL BE MADE BY ELECTRICAL CONTRACTOR. MECHANICAL UNIT CONTROL (SHUTDOWN UPON DETECTOR ALARM) WIRING AND CONNECTIONS SHALL BE MADE BY MECHANICAL CONTRACTOR.
- APPROVED NOTIFICATION APPLIANCES FOR THE HEARING IMPAIRED SHALL BE INSTALLED IN ACCORDANCE WITH NFPA REQUIREMENTS IN THE FOLLOWING AREA: RESTROOMS, CORRIDORS, OCCUPIED ROOMS WHERE AMBIENT NOISE IMPAIRS HEARING OF THE FIRE ALARM, LOBBIES, MEETING ROOMS, AND OTHER AREA FOR COMMON USE. (ONLY REQUIRED IF PROJECT COMPLY TO ITEM 6 BELOW)

## SHEET INDEX


SHEET NO.	SHEET DESCRIPTION
E0.1	ELECTRICAL GENERAL NOTES
E0.2	LEGEND, ABBREVIATIONS, AND SINGLE LINE DIAGRAM
E0.3	PANEL SCHEDULES
ES1	ELECTRICAL SITE PLAN
E1.1	OVERALL ELECTRICAL FLOOR PLANS
E2.1	ENLARGED POWER, MECHANICAL, PLUMBING CONNECTION PLAN
E2.2	ENLARGED UPS POWER AND COMMUNICATION FLOOR PLAN
E2.3	ENLARGED LIGHTING CONTROL PLAN
E2.4	ENLARGED LIGHTING PLAN AND FIXTURE SCHEDULE
E3.1	ELECTRICAL ROOF AND GROUNDING/BONDING PLANS
E4.1-E4.3	ELECTRICAL DETAILS
E5.1	LIGHTING ENERGY COMPLIANCE FORMS

## POWER PLAN NOTES

- FUSING: ALL FUSIBLE SAFETY DISCONNECT SWITCHES SHALL BE PROVIDED WITH DUAL-ELEMENT TIME DELAY TYPE FUSES SIZED AND RATED PER EQUIPMENT MANUFACTURERS' RECOMMENDATIONS. VERIFY WITH EQUIPMENT NAMEPLATE BEFORE INSTALLATION.
- INSTALL SEPARATE NEUTRALS FOR EACH 120V BRANCH CIRCUIT.
- MOTOR OVERLOAD PROTECTION: WHERE REQUIRED BY NEC ARTICLE 430 PART C AND NOT SHOWN ON PLAN OR PROVIDED INTEGRAL WITH EQUIPMENT, PROVIDE AND INSTALL THERMAL OVERLOAD PROTECTION FOR ALL MOTORS.
- SPARE CONDUIT FOR RECESSED PANELS: PROVIDE (1) 3/4" SPARE CONDUIT STUB UP TO ACCESSIBLE ABOVE CEILING SPACE AND/OR ACCESSIBLE SPACE BELOW FOR EVERY (3) SPARE BREAKER SPACES AS INDICATED ON PANEL SCHEDULES.
- DEVICE LOCATIONS SHOWN ARE SCHEMATIC AND APPROXIMATE. EXACT LOCATIONS SHALL BE FIELD VERIFIED DURING ROUGH-IN WITH ARCHITECTURAL ELEVATIONS, CASEWORK SHOP DRAWINGS, FURNITURE, ETC. AND SHALL BE COORDINATED WITH OTHER TRADES TO AVOID CONFLICT WITH OTHER EQUIPMENT.
- ELECTRICAL AND COMMUNICATIONS OUTLETS SHOWN IN THE SAME LOCATION, SHALL BE MOUNTED ON OPPOSITE SIDES OF THE SAME STUD. COORDINATE BETWEEN ELECTRICAL AND COMMUNICATIONS PLANS.

## LIGHTING PLAN NOTES

- NIGHT LIGHT "NL" DESIGNATED LUMINAIRES IN INTERIOR LOCATIONS SHALL HAVE ONE BALLAST CONTINUOUSLY ENERGIZED. LUMINAIRES IN EXTERIOR LOCATIONS SHALL BE AUTOMATICALLY CONTROLLED TO BE ON FROM DUSK TO DAWN.
- LIGHTING FIXTURE LOCATIONS SHOWN ARE SCHEMATIC. REFER TO ARCHITECTURAL PLANS (REFLECTED CEILING, ELEVATIONS, ETC.) FOR EXACT LOCATIONS AND MOUNTING HEIGHTS PRIOR TO ROUGH-IN.
- REFER TO ARCHITECT'S REFLECTED CEILING PLAN(S) FOR CEILING HEIGHTS, TYPES, FINISHES, ETC. IN EACH AREA. VERIFY FLANGE TYPES, TRIM KITS, STEM LENGTHS, ETC. FOR ALL FIXTURES PRIOR TO SUBMITTALS.
- CONFIRM LOCATION OF ALL DOORS SWINGS WITH ARCHITECTURAL PLANS PRIOR TO ROUGH-IN OF SWITCHES.
- PROVIDE UNSWITCHED HOT LEG OF ROOM LIGHTING BRANCH CIRCUIT TO EACH BATTERY POWERED EMERGENCY LIGHT AND EXIT SIGN FOR CONTINUOUS CHARGING.



**Chas Rhoads**  
 Architecture  
 Interiors  
 Landscape

128 Katherine Street - Hanford - California - 93230  
 Phone: 539 - 584 - 3371

Postal Box 221 - Morro Bay - California - 93443  
 Phone: 805 - 234 - 6220

Email: chasrhoads@sbcglobal.net



Drawing Status:

Contract Document

Revision Summary:

Project:  
**New Dispatch Center  
 Tulare County Sheriff & Fire**  
 5300 West Tulare Avenue  
 Visalia, California

Sheet Description:  
**Electrical General Notes**

Date: 8/8/2020  
 Project: 19-700  
 Scale: NOTED

Sheet No.:

**E0.1**

Of x Sheets

# LEGEND

NOTE: INTERPRET IN CONTEXT


MISCELLANEOUS	CONDUIT/WIRE	POWER	
<ul style="list-style-type: none"> <li>MOTOR</li> <li>THERMOSTAT</li> <li>CIRCUIT BREAKER</li> <li>FUSIBLE SWITCH</li> <li>GROUND</li> <li>PHASE</li> <li>CLOCK</li> <li>CLOCK/SPEAKER COMBINATION</li> <li>WALL MOUNTED CLOCK</li> <li>PUSHBUTTON</li> <li>FLUSHMOUNT PANEL</li> <li>SURFACEMOUNT PANEL</li> <li>FLUSHMOUNT CABINET</li> <li>SURFACEMOUNT CABINET</li> <li>DAMPER MOTOR</li> <li>HUMIDISTAT</li> <li>MAGNETIC CONTACTOR</li> <li>COMBINATION STARTER</li> <li>SAFETY DISCONNECT</li> <li>SECURITY CAMERA</li> </ul>	<ul style="list-style-type: none"> <li>NEW</li> <li>UNDERGROUND</li> <li>NEW POWER HOMERUN (3 HOTS &amp; NEUT SHOWN)</li> <li>CONDUIT SEAL</li> <li>INDICATES LINE CONTINUES</li> <li>CONDUIT STUB (W/MARKER)</li> <li>FLEXIBLE CONNECTION</li> </ul>	<ul style="list-style-type: none"> <li>DUPLEX RECEPTACLE</li> <li>PROVIDE ARC FAULT BREAKER (GFCI) GROUND FAULT CURRENT INTERRUPTER DEVICE</li> <li>MOUNT ABOVE COUNTER PER ADA. REFER TO ARCH.</li> <li>MOUNT AT 48" MEASURED TO TOP OF BOX.</li> <li>208V RECEPTACLE</li> <li>WHILE-IN USE NEMA 3R COVER (TAYMAC #MX4280S OR ENGINEER APPROVED EQUAL)</li> <li>(1) CONTROLLED DUPLEX RECEPTACLE AND (1) DUPLEX RECEPTACLE</li> <li>DUPLEX OUTLET FOR TELEVISION OUTLET. VERIFY MOUNTING HEIGHT PRIOR TO ROUGH-IN.</li> <li>GROUND BAR</li> <li>CEILING MOUNTED OUTLET</li> <li>SWITCH RECEPTACLE</li> <li>GANG WITH SWITCH</li> <li>DISCONNECT FUSE OR NON FUSED</li> </ul>	
	DATA		
	<ul style="list-style-type: none"> <li>DATA OUTLET. PROVIDE 58 BOX WITH 1-1/4" O.D. TO ACCESSIBLE CEILING SPACE FOR LOW VOLTAGE WIRING BY OWNER'S VENDOR.</li> <li>TV OUTLET FOR TELEVISION. MOUNT ADJACENT TO POWER OUTLET. VERIFY MOUNTING HEIGHT PRIOR TO ROUGH-IN. PROVIDE 4S BOX WITH 1" O.D. TO ACCESSIBLE CEILING SPACE FOR LOW VOLTAGE WIRING BY OWNER'S VENDOR.</li> <li>WIRELESS ACCESS POINT.</li> </ul>		
LIGHT FIXTURES	WORKSTATION DATA	DOOR ACCESS	CONVENTION
<ul style="list-style-type: none"> <li>RECESSED LED TROFFER (2'x4')</li> <li>RECESSED LED TROFFER (2'x2')</li> <li>LED UNDERCABINET LIGHT</li> <li>RECESSED CAN LIGHT</li> <li>EXIT LIGHT - WALL</li> <li>EXIT LIGHT - CEILING (ARROW INDICATES DIRECTION)</li> <li>LETTER ADJACENT INDICATES FIXTURE TYPE</li> </ul>	<ul style="list-style-type: none"> <li>DISPATCH 911 DATA LINES</li> <li>COUNTY DATA LINES</li> <li>DB25 CABLES</li> </ul> <p>NOTE: VERIFY POINT OF CONNECTION AT EACH WORKSTATION. ROUTE CABLES BELOW RAISE FLOOR. 'X' DENOTES TOTAL CABLE DROP.</p>	<ul style="list-style-type: none"> <li>CARD READER. PROVIDE 1/2" O.D. TO ACCESSIBLE CEILING SPACE. VERIFY ROUGH-IN REQUIREMENTS WITH CARD READ MANUFACTURER.</li> <li>DOOR CONTACT. VERIFY ROUGH-IN REQUIREMENTS WITH CARD READ MANUFACTURER.</li> </ul>	<ul style="list-style-type: none"> <li>NUMBERED SHEET NOTES: REFERS TO NOTES ON SAME SHEET AS REFERENCE</li> <li>DETAIL REFERENCE: Z = DETAIL DESIGNATION X = SHEET NUMBER REFERENCE</li> <li>FEEDER SCHEDULE DESIGNATION (EXAMPLE: 3103 = 310 AMPERE, 600V, 3 CURRENT CARRYING CONDUCTORS, PREFIXES: 'M' INDICATES MEDIUM VOLTAGE, '014' INDICATES CONDUIT ONLY, QUANTITY (1) AND SIZE (4")</li> </ul>

# ABBREVIATIONS

A AMPERE	(E) EXISTING	IG ISOLATED GROUND	PA PUBLIC ADDRESS	UL UNDERWRITERS LABORATORIES
AB AMP BREAKER	EA EACH	J-BOX JUNCTION BOX	PB PULLBOX	UNLESS OTHERWISE NOTED
ABAND ABANDONED	EB ELECTRONIC BALLAST	K QUANTITY 1000	PC PULL CHAIN	USG UNDERGROUND
ABV ABOVE	EC ELECTRICAL CONTRACTOR	KVA KILOWATT	PC PHOTOCELL	USA USG VOLT ALERT 800-842-2444
AC ALTERNATING CURRENT	EC# EVAPORATIVE COOLER	KW KILOWATT	PC PLUMBING CONTRACTOR	V VOLT
AC# AIR CONDITIONER	EF# EXHAUST FAN	LC LIGHTING CONTRACTOR	PC PLUMBING CONTRACTOR	VA VOLT AMPERES
ADJ ADJACENT	EL EVENING LIGHT	LPS LOW PRESSURE SODIUM	PNL PANEL	VAC VOLT ALTERNATING CURRENT
AF AMP FUSE, AMP FRAME	ELEC ELECTRICAL	LRA LOCKED ROTOR AMPS	POC POINT OF CONNECTION	VHO VERY HIGH OUTPUT
AF# ABOVE FINISH FLOOR	EMERG EMERG BATTERY BACKUP EMERGENCY	LS LIFE SAFETY BRANCH	PP- POWER PRIMARY	VLT VOLTAGE
AFG ABOVE FINISH GRADE	EMERG EMERG BATTERY BACKUP EMERGENCY	LT LIGHT	PS- POWER SECONDARY	VR VANDAL-RESISTANT
AIC AMPERES INTERRUPTING CAPACITY	EMERG EMERGENCY	LTG LIGHTING	PV PHOTOVOLTAIC	W WIDTH, WATT, WIRE
AI ALUMINUM	EOL END OF LINE	LV LOW VOLTAGE	RELOC (R) RELOCATED	WH# WATER HEATER
AS AMP SWITCH RATING	EQUIP EQUIPMENT	MC MECHANICAL CONTRACTOR	RECEPT RECEPTACLE	WP WEATHERPROOF (NEMA 3R)
ATS AUTOMATIC TIME SWITCH	ES ENERGY SAVING	MCA MINIMUM CKT AMPS	REF REFRIGERATOR	XFMR TRANSFORMER
ATS AUTOMATIC TRANSFER SWITCH	(E) IN (R) LOCATION	MCB MAIN CIRCUIT BREAKER	REQD REQUIRED	+48 INDICATES MOUNTING HEIGHT AFF
AV AUDIBLE/AUDIO VISUAL	(E) TO BE (R)	MCTB MAIN CATV TERMINAL BOARD	RLA ROOM LOAD AMPS	
AWG AMERICAN WIRE GAUGE	EXT EXTERIOR	MCTC MAIN CATV TERMINAL CABINET	RM ROOM	
BFG BELOW FINISH GRADE	F FLUORESCENT	MECH MECHANICAL	RMC RIGID METAL CONDUIT	
BL BASIC IMPULSE LEVEL	(F) FUTURE	MFR MANUFACTURER	RMV REMOVE	
BLDG BUILDING	F# FIRE ALARM	MFS MAIN FUSIBLE SWITCH	RFLC REPLACE	
C CATV CONDUIT	FACP FIRE ALARM CONTROL PANEL	MLO MAIN LUGS ONLY	RPS RAMP START	
CABT CABINET	FAT FIRE ALARM TERMINAL	MOCB MAIN SWITCHBOARD	SC SIGNAL CABINET	
CATV CABLE TELEVISION	FBU FORCED AIR UNIT	MSB MAIN SWITCHBOARD	SCC SHORT CKT CURRENT	
CB CIRCUIT BREAKER, CODE BLUE	FBO FURNISHED BY OTHERS	MT MOUNT	SFM STATE FIRE MARSHAL	
CEC CA ELECTRICAL CODE	FLA FAN COIL	MT HT MOUNTING HEIGHT	SHT SHEET	
CEC CA ELECTRICAL CODE	FLR FULL LOAD AMPS	MTS MANUAL TRANSFER SWITCH	SL SLIMLINE, SWITCH LEG	
CF CA ENERGY COMMISSION	FLR FLOOR	MTTB MAIN TELEPHONE SWITCH	SPEC SPECIFICATION	
CF COMPACT FLUORESCENT	FLR FLUORESCENT	MTTB MAIN TELEPHONE TERMINAL BOARD	SPST SINGLE POLE SINGLE THROW	
CF CALIFORNIA FIRE CODE	FS FLUORESCENT SWITCH	MS MAIN TELEPHONE TERMINAL CABINET	SG SQUARE	
CLG CEILING	FVNR FULL VOLTAGE NON-REVERSING	MW MICROWAVE	STRG STORAGE	
CLG CENTER LINE	G GROUNDING CONDUCTOR	N NEUTRAL (GROUNDED CONDUCTOR)	SURF SURFACE	
CLG CENTER LINE	GC GENERAL CONTRACTOR	(N) NEW	SVC SERVICE	
CONTR CONTRACTOR	GC GARBAGE DISPOSAL	NC NORMALLY CLOSED	SW SWITCH	
C.O. CONDUIT ONLY (W/PULLROPE)	GFCI GROUND FAULT CIRCUIT INTERRUPTER	NEC NATIONAL ELECTRICAL CODE	T TRANSFORMER, TERMINAL	
COND CONDUIT, CONDUIT	GFI GROUND FAULT CIRCUIT INTERRUPTER	NATL. ELEC MANUFACTURER'S ASSOC	-T- TELEPHONE CONDUIT TO BE REMOVED	
CR CRITICAL BRANCH	GND GROUND	NIC NOT IN CONTRACT	(TBR) TELEPHONE COMPANY	
CSFM CALIFORNIA SFM	GRS GALVANIZED RIGID STEEL	NL NIGHT LIGHT	TEL TELEPHONE	
CT CURRENT TRANSFORMER	GWS GANG WITH SWITCH	NO NORMALLY OPEN	TELO TELEPHONE COMPANY	
Cu COPPER	H HEIGHT, HIGH	NPF NORMAL POWER FACTOR	TS TIME SWITCH	
CU# CONDENSING UNIT	HACR HEATING, AC & REFRIG	NTS NOT TO SCALE	TSO TIME SWITCH OVERRIDE	
D DEPTH	HID HIGH INTENSITY DISCHARGE	ND ON CENTER	TSP TWISTED SHIELD PAIR	
DC DIRECT CURRENT	HO HIGH OUTPUT	OCP OVERCURRENT PROTECTION	TB TELEPHONE TERMINAL BOARD	
DF DRINKING FOUNTAIN	HOA HAND-OFF-AUTO	OD OUTSIDE DIAMETER	TTC TELEPHONE TERMINAL CABINET	
DIA DIAMETER	HP HORSEPOWER	OH OVERHEAD	TX TRANSFORMER	
DISC DISCONNECT	HPF HIGH POWER FACTOR	OSA OFFICE OF THE STATE ARCHITECT	TYP TYPICAL	
DISC DISTRIBUTION	HPS HIGH PRESSURE SODIUM	OSHPD OFFICE OF STATEWIDE HEALTH PLANNING & DEVELOPMENT	TYP SM TYPICAL SIMILAR	
DPST DOUBLE POLE SINGLE THROW	ID IDENTIFICATION	OVLD OVERLOAD	UC UNDERCABINET UNDERCOUNTER	
DW DISHWASHER	IF INSIDE FROST	P POLE	UG UNDERGROUND	
EM EMERGENCY			UGPS UNDERGROUND PULL SECTION	


# CIRCUITING LEGEND

## LIGHTING PLAN



- PROVIDE ALL BRANCH CIRCUIT WIRING FROM FIXTURES TO PANEL(S) AS DESCRIBED BY CIRCUIT NUMBERS SHOWN.
- PROVIDE ALL WIRING BETWEEN FIXTURES AND CONTROL DEVICES AS DESCRIBED IN REFERENCE NOTES AND/OR SHOWN BY SWITCH/LEG DESIGNATIONS.
- EXIT AND EMERGENCY LIGHT FIXTURES SHALL BE CONNECTED TO AN UNSWITCHED BRANCH CIRCUIT CONDUCTOR.
- HOME RUN CONDUITS SHALL BE 3/4", MAX OF (3) BRANCH CIRCUITS PER CONDUIT.
- PROVIDE ALL BRANCH CIRCUIT WIRING FROM MECH. EQUIPMENT TO PANELS.


## POWER PLAN



- PROVIDE ALL BRANCH CIRCUIT WIRING FROM DEVICES TO PANEL(S) PER DESIGNATIONS/CIRCUIT NUMBERS.
- EACH BRANCH CIRCUIT SHALL HAVE A SEPARATE NEUTRAL AS INDICATED ON PANEL SCHEDULES.
- HOME RUN CONDUITS SHALL BE 3/4", MAX OF (3) BRANCH CIRCUITS PER CONDUIT.
- INCREASE HOME RUN CONDUIT SIZE TO 1" FOR (4) BRANCH CIRCUITS OR MORE.
- (\*\*) DENOTES SPECIAL DEVICE/NAMEPLATE REQUIREMENTS.


NOTE: THE INTENT OF THE DRAWINGS IS TO SHOW FIXTURE / DEVICE LOCATIONS AND PANEL DESIGNATIONS. ALL BRANCH CIRCUIT WIRING, MEETING THE CRITERIA NOTED ABOVE, WILL BE THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR. LIGHTING AND POWER PLANS SHOW AN ABOVE CEILING JUNCTION BOX / HOME RUN WITH CIRCUIT NUMBERS BY FIXTURES / DEVICES. PROVIDE ALL BRANCH CIRCUITING AS REQUIRED FOR A COMPLETE INSTALLATION. DOCUMENT ALL BRANCH CIRCUITING ON AS-BUILT DRAWINGS ACCURATELY REFLECTING THE INSTALLATION.

# SINGLE LINE DIAGRAM



# SINGLE LINE DIAGRAM NOTES

- ALL CONDUCTORS SHALL BE COPPER WITH TYPE [THHN/THWN] INSULATION UNLESS OTHERWISE NOTED.
- ALL SWITCHES, CIRCUIT BREAKERS AND OTHER EQUIPMENT, AS SPECIFIED, SHALL HAVE TERMINATION PROVISIONS LISTED AND IDENTIFIED FOR USE WITH 75 DEG. CONDUCTORS, AND ALL FEEDER CONDUCTORS, AND CONDUITS, ARE SIZE BASED ON USE OF 75 DEG. C COPPER WIRES TYPE THWN/THHN.
- DESIGN SHOWN IS BASED ON SQUARE D PANEL PRODUCT AND EATON UPS. ENGINEER-APPROVED EQUAL ALTERNATE PRODUCT WILL BE ACCEPTABLE.
- ALL EQUIPMENT SHALL HAVE AN APPROVED TESTING LABORATORY LABEL ATTACHED [UL, CSA, ETC.] (CEC 110-2).
- THE ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR SUPPLYING SWITCHGEAR SIZED TO FIT IN THE AVAILABLE SPACE IN THE ELECTRIC ROOM. REFER TO ARCHITECTURAL PLANS FOR DIMENSIONAL INFORMATION NOT SHOWN ON THE ELECTRICAL PLANS. CONTRACTOR SHALL SUBMIT A 1/4" SCALE DRAWING OF ALL ELECTRICAL EQUIPMENT IF SUBSTITUTING PRODUCTS.
- PER CALIFORNIA TITLE 24 SECTION 130.5, WIRING PROVISIONS HAVE BEEN MADE FOR DISAGGREGATION OF THE ELECTRICAL CIRCUITS, THE OPTIONAL METERING HAS NOT BEEN PROVIDED FOR THIS PROJECT.
- REFER TO PANEL SCHEDULES FOR INDIVIDUAL BRANCH CIRCUIT VOLTAGE DROP AND/OR SINGLE LINE DIAGRAM FOR FEEDER VOLTAGE DROP CALCULATIONS.
- BRANCH CIRCUIT/FEEDER DISTANCE IS SHOWN FOR REFERENCE ONLY AS THE BASIS OF VOLTAGE DROP CALCULATIONS. CONDUCTOR DISTANCE AS INDICATED SHALL NOT BE USED FOR BIDDING/CONSTRUCTION PURPOSES. SHOULD THE FEEDER DISTANCE EXCEED THE LENGTH NOTED PER INSTALLATION CONDITIONS, NOTIFY THE ENGINEER OF RECORD. TYPICAL.



**Chas Rhoads**  
Architecture  
Interiors  
Landscape

128 Katherine Street - Hanford - California - 93230  
Phone: 559 - 584 - 3371

Postal Box 221 - Morro Bay - California - 93443  
Phone: 805 - 234 - 6220

Email: chasrhoads@sbcglobal.net



Consultant:  
**Thomas Engineering, Inc.**  
THOMA ENGINEERING, INC.  
P.O. Box 1167 - 3562 Empeleo St.  
San Luis Obispo, CA 93406  
Phone: (805) 543-3850  
Fax: (805) 543-3829  
cad@thomaelec.com

Drawing Status:

**Contract Document**

Revision Summary:

Revision	Description


Project:  
**New Dispatch Center  
Tulare County Sheriff & Fire**

**5300 West Tulare Avenue  
Visalia, California**

Sheet Description:  
**Legend, Abbreviations, Single  
Line Diagram**

Date: 8/8/2020  
Project: 19-700  
Scale: NOTED  
Sheet No.: **E0.2**  
Of 3 Sheets





**Chas Rhoads**  
 Architecture  
 Interiors  
 Landscape

128 Katherine Street - Hanford - California - 93230  
 Phone: 539 - 584 - 3371  
 Postal Box 221 - Morro Bay - California - 93443  
 Phone: 805 - 234 - 6220  
 Email: chasrhoads@sbcglobal.net



Consultant:  
**Thoma ENGINEERING**  
 THOMA ELECTRIC, INC.  
 P.O. Box 1167 - 3562 Empelee St.  
 San Luis Obispo, CA 93406  
 Phone: (805) 543-3850  
 Fax: (805) 543-3829  
 cad@thomaelec.com

Drawing Status:


**Contract Document**

Revision Summary:


Project:  
**New Dispatch Center**  
**Tulare County Sheriff & Fire**  
**5300 West Tulare Avenue**  
**Visalia, California**


Sheet Description:  
**Electrical Site Plan**

Date:	8/8/2020
Project:	19-700
Scale:	NOTED
Sheet No.:	<b>ES.1</b>
Of x Sheets	




**ELECTRICAL SITE PLAN**  
 SCALE: 1" = 50'-0"  
 NORTH


NOTE: REFER TO SHEET SD1 AND SD2 FOR ADDITIONAL REQUIREMENTS



**OVERALL ELECTRICAL FIRST FLOOR PLAN**  
 SCALE: 1" = 30'-0"  
 NORTH




**OVERALL ELECTRICAL SECOND FLOOR PLAN**  
 SCALE: 1" = 30'-0"  
 NORTH



**Chas Rhoads**  
 Architecture  
 Interiors  
 Landscape

128 Katherine Street - Hanford - California - 93230  
 Phone: 539 - 584 - 3371  
 Postal Box 221 - Morro Bay - California - 93443  
 Phone: 805 - 234 - 6220  
 Email: chasrhoads@sbcglobal.net



Drawing Status:

**Contract Document**


Revision Summary:


Project:  
**New Dispatch Center**  
**Tulare County Sheriff & Fire**  
**5300 West Tulare Avenue**  
**Visalia, California**

Sheet Description:  
**Overall Electrical Floor Plans**

Date:	8/8/2020
Project:	19-700
Scale:	NOTED
Sheet No.:	E1.1


Of x Sheets




**1** ENLARGED POWER, MECHANICAL, PLUMBING CONNECTION PLAN  
SCALE: 1/4" = 1'-0"

**REFERENCE NOTES**

1. OUTDOOR UNIT POWERS INDOOR UNIT. PROVIDE LINE VOLTAGE WIRES BETWEEN INDOOR AND OUTDOOR UNIT.
2. PROVIDE 120V AND FIRE ALARM CONNECTION TO SMOKE DUCT DETECTOR PER MECHANICAL PLANS.
3. TO POWER SUPPLY FOR CONTROLLED RECEPTACLE. REFER TO LIGHTING CONTROL PLANS.
4. PROVIDE 120V CONNECTION TO TEMPERATURE SENSOR PER MECHANICAL PLANS.
5. CLOCK OUTLET. REFER TO ARCHITECT ELEVATION FOR EXACT LOCATION PRIOR TO ROUGH-IN.
6. CONNECTION TO PRINTER.
7. 480V, 3Ø DISCONNECT WITH LOCKABLE HANDLE PER SINGLE LINE DIAGRAM.
8. VERIFY POINT OF CONNECTION AT WORK STATION. ROUTE CONDUITS UNDER RAISE FLOOR. HOMERUN BRANCH CIRCUIT TO PANEL "PD." THIS CONNECTION IS FOR (2) CONVENIENCE OUTLETS AND (1) CONSOLE POWER STRIP. COORDINATE WITH OWNER'S VENDOR.
9. MOUNT TO OUTLET TO OUTDOOR UNIT.
10. BRANCH CIRCUIT UP TO ROOF MOUNTED OUTLET.



**2** ELECTRICAL ENLARGED PLAN AT RADIO ROOM [21]  
SCALE: 1/4" = 1'-0"



**Chas Rhoads**  
Architecture  
Interiors  
Landscape

128 Katherine Street - Hanford - California - 93230  
Phone: 539 - 584 - 3371  
Postal Box 221 - Morro Bay - California - 93443  
Phone: 805 - 234 - 6220  
Email: chasrhoads@sbcglobal.net




Drawing Status: Contract Document

Revision Summary:


Project:  
**New Dispatch Center  
Tulare County Sheriff & Fire**  
5300 West Tulare Avenue  
Visalia, California


Sheet Description:  
**Enlarged Power, Mechanical,  
& Plumbing Connection Plan**

Date:	8/8/2020
Project:	19-700
Scale:	NOTED
Sheet No.:	<b>E2.1</b>
Of x Sheets:	




**REFERENCE NOTES**

1. PROVIDE 3/4" FIRE RATED BACKBOARD (PAINTED) PLYWOOD 8FT HEIGHT INSTALLED ON THREE WALL AS SHOWN.
2. 12" WIDE OVERHEAD LADDER TRY. INSTALLED/FURNISHED BY OWNER'S VENDOR.
3. STANDARD 7FT UNIVERSAL TWO POST RACK WITH VERTICAL WIRE MANAGEMENT. INSTALLED/FURNISHED BY OWNER'S VENDOR.
4. STUB (4) 4" (EMT) TO ROOF FOR COAXIAL FEED LINE PROVIDE WEATHERHEAD CAP.
5. AT&T VIPR CABINET BY AT&T.
6. (4) 4" (EMT) CONDUIT BETWEEN SECOND FLOOR RADIO ROOM AND IDF.
7. CONNECTION TO DOOR ACCESS CONTROL. REFER TO DETAILS 7 AND 8 ON SHEET
8. EMT CONDUIT SLEEVE(S) STUB TO RAISE FLOOR.
9. EMT CONDUIT SLEEVES UP TO ACCESSIBLE CEILING SPACE.
10. (2) 4" (EMT) TO SECOND FLOOR DATA ROOM.
11. VERIFY POINT OF CONNECTION AT EACH WORK STATION. PROVIDE (2) DEDICATED CIRCUITS EACH FOR CUSTOMER EQUIPMENT (5) POWER STRIPS. ROUTE BRANCH BELOW RAISE FLOOR. HOMERUN BRANCH CIRCUIT TO PANEL UP "PU."
12. PROVIDE NEMA 15-30R OUTLETS.
13. STUB 1" CONDUIT DOWN TO HALL 1 ROOM 10 ACCESSIBLE CEILING SPACE FOR DOOR ACCESS LOW VOLTAGE WIRING TO ROOM 21.
14. STUB 2" CONDUIT SLEEVES ABOVE ACCESSIBLE CEILING SPACE FOR DOOR ACCESS LOW VOLTAGE WIRING.



**ELECTRICAL ENLARGED PLAN AT RADIO ROOM [21]**  
SCALE: 1/4" = 1'-0"

**1 ENLARGED UPS POWER AND COMMUNICATION PLAN**  
SCALE: 1/4" = 1'-0"



**Chas Rhoads**  
Architecture  
Interiors  
Landscape

128 Katherine Street - Hanford - California - 93230  
Phone: 539 - 584 - 3371  
Postal Box 221 - Morro Bay - California - 93443  
Phone: 805 - 234 - 6220  
Email: chasrhoads@sbcglobal.net



Drawing Status: **Contract Document**

Revision Summary:


Project:  
**New Dispatch Center  
Tulare County Sheriff & Fire**  
5300 West Tulare Avenue  
Visalia, California

Sheet Description:  
**Enlarged UPS Power and  
Communication Plan**

Date:	8/8/2020
Project:	19-700
Scale:	NOTED
Sheet No.:	<b>E2.2</b>
Of x Sheets:	


Aug 20, 2020 - 3:30pm - c:\cbs - K:\ENG\2018\19-700\19-8135\_E22\_ENLARGED UPS POWER AND COMMUNICATION FLOOR PLAN.dwg

# LIGHTING CONTROLS SEQUENCE OF OPERATIONS

SPACE	LIGHTING CONTROL SEQUENCE
HALLWAYS	<ul style="list-style-type: none"> <li>OCCUPANCY: LIGHTS AUTOMATICALLY TURN ON TO 100% WHEN THE USER ENTERS THE ROOM AND 15 MINUTES AFTER SPACE HAS BEEN VACATED, THE LIGHTS WILL AUTOMATICALLY GO TO 50%.</li> <li>MANUAL DIMMER WILL ALLOW OCCUPANT TO CONTROL EACH ZONE. WALL STATION SHALL HAVE ONE BUTTON PER ZONE AS CALLED OUT ON PLAN.</li> <li>EMERGENCY LIGHTING SHALL TURN ON WHEN NORMAL POWER SHUTS OFF OR UPON ACTIVATION OF EMERGENCY ALARM</li> </ul>
QUIET AND STAFF ROOM	<ul style="list-style-type: none"> <li>OCCUPANCY: LIGHTS AUTOMATICALLY TURN ON TO 100% WHEN THE USER ENTERS THE ROOM AND 15 MINUTES AFTER THE ROOM HAS BEEN VACATED, THE LIGHTS WILL AUTOMATICALLY TURN OFF.</li> <li>MANUAL DIMMER WILL ALLOW OCCUPANT TO CONTROL THE LIGHTS</li> </ul>
OFFICES	<ul style="list-style-type: none"> <li>ALL OTHER LIGHTS MUST BE TURNED ON MANUALLY BY OCCUPANT</li> <li>MANUAL DIMMER WILL ALLOW OCCUPANT TO CONTROL</li> <li>LIGHTS WILL SHUT-OFF WHEN SPACES VACATED VIA OCCUPANCY SENSOR.</li> </ul>
STORAGE	<ul style="list-style-type: none"> <li>OCCUPANCY: USER MANUALLY TURNS ON LIGHTS UPON ENTRY. 15 MINUTES AFTER THE ROOM HAS BEEN VACATED, THE LIGHTS WILL AUTOMATICALLY TURN OFF.</li> <li>MANUAL DIMMER WILL ALLOW OCCUPANT TO CONTROL THE LIGHTS</li> </ul>
DISPATCH ROOMS	<ul style="list-style-type: none"> <li>ALL OTHER LIGHTS MUST BE TURNED ON MANUALLY BY OCCUPANT</li> <li>NUMBER OF ZONES OF LIGHTING CONTROL AS NOTED ON PLANS</li> <li>MANUAL DIMMER WILL ALLOW OCCUPANT TO CONTROL EACH ZONE.</li> <li>LIGHTS IN DAYLIGHT ZONES (WHERE NOTED ON PLANS) WILL AUTOMATICALLY DIM A MINIMUM OF 65% WHEN AVAILABLE DAYLIGHT IS 150% OF DESIGN ILLUMINATION.</li> <li>LIGHTS WILL SHUT-OFF WHEN SPACES VACATED VIA OCCUPANCY SENSOR.</li> </ul>

# LUTRON LEGEND

- LUTRON #QSN-4T16-S ENERGI SAVR NODE 0-10V AND SOFTSWITCH (MOUNT ABOVE ACCESSIBLE CEILING SPACE)
- LUTRON #QSMX-4W-C QS SENSOR MODULE WIRED INPUTS ONLY (CEILING MOUNT)
- LUTRON #MSCL-OP153M-WH MAESTRO PASSIVE INFRARED SENSOR OCCUPANCY SENSOR WITH C.L. WALL DIMMER (600W INCANDESCENT/HALOGEN, 150W CFL/LED)
- LUTRON #MS-Z101-WH MAESTRO PASSIVE INFRARED SENSOR OCCUPANCY SENSOR WITH DIMMER (0-10V), (WALL MOUNT)
- LUTRON #QSW2-2BRLI-WH QS 2-BUTTON WITH RAISE/LOWER (WALL MOUNT)
- LUTRON #QSW2-BRLI-WH QS 5-BUTTONS WITH RAISE/LOWER (WALL MOUNT)
- LUTRON #EC-DR-WH CEILING MOUNT DAYLIGHT SENSOR WITH INFRARED RECEIVER
- LUTRON #LOX-CDT-500-WH CEILING MOUNT DUAL TECHNOLOGY OCCUPANCY SENSOR 500SF
- LUTRON #LRF2-OC42B-P RADIO PWR SAVR WIRELESS CEILING OCCUPANCY SENSOR
- LVS, INC. #LUT-ALCR-D UL924 EMERGENCY BYPASS RELAY FOR 0-10V FIXTURES. MOUNT ABOVE ACCESSIBLE CEILING SPACE.
- LUTRON #RMS-20R-DV-B PMPAK RELAY MODULE TO CONTROL 20A RECEPTACLES. (MOUNT ABOVE ACCESSIBLE CEILING SPACE)
- LUTRON #QSPS-10PIL SMART PANEL FOR SIVOIA QS WINDOW SHADES. (MOUNT ABOVE T-BAR CEILING)



**LIGHTING ENLARGED PLAN AT RADIO ROOM [21]**  
SCALE: 1/4" = 1'-0"

### LUTRON SERVICE DESCRIPTION:


THE COUNTS OF SERVICES BELOW ARE TO BE INCLUDED AS PART OF THE PROJECTS SCOPE OF WORK AND SPECIFIED INTO THE WRITTEN SPEC DOCUMENTS.

- ON SITE PRE-WIRE VISIT (LSC-PREWIRE): ONSITE VISIT WITH ELECTRICAL CONTRACTOR TO DISCUSS LOGISTICAL CONSTRUCTION CONSIDERATION INCLUDING WIRING AND MOUNTING OF SYSTEM DEVICES, CONSTRUCTION SCHEDULE, AND LUTRON DOCUMENTATION.
- TITLE 24 ACCEPTANCE TEST VISIT (LSC-SPV-DOC-T24): ACCEPTANCE TESTING BY A LUTRON CERTIFIED LIGHTING CONTROL ACCEPTANCE TEST TECHNICIAN (CLCATT) TO FULFILL THE REQUIRED TITLE 24 INTERIOR LIGHTING CONTROL TEST.
- FACTORY ONSITE START UP FOR STANDALONE QS (LSC-OS-SU-QS)
- FACTORY ONSITE START UP FOR VIVE SYSTEM (LSC-OS-SU-VIVE)


### QUANTITY AND LOCATION OF ALL SENSORS ARE SHOWN FOR DESIGN INTENT. LIGHTING CONTROL MANUFACTURER SHALL SUBMIT COMPLETE SHOP DRAWING SHOWING PREFERRED LOCATION AND QUANTITY OF SENSORS REQUIRED FOR OPTIMUM SYSTEM PERFORMANCE.

PROVIDE OCCUPANCY SENSOR, WALL OR CEILING MOUNTED AS SHOWN ON THIS PLAN WITH TYPE AND MODEL THAT CAN ACCOMMODATE THE SPACE REQUIREMENT FOR THE ROOM OR AREA.

(EM) LIGHTS AND EXIT SIGNS SHOWN ARE CONNECTED TO EMERGENCY LIGHTING INVERTER. PROVIDE SEPARATE BRANCH CIRCUIT RACEWAY.



**1 ENLARGED LIGHTING CONTROL PLAN**  
SCALE: 1/4" = 1'-0"



**Chas Rhoads**  
Architecture  
Interiors  
Landscape

128 Katherine Street - Hanford - California - 93230  
Phone: 539 - 584 - 3371

Postal Box 221 - Morro Bay - California - 93443  
Phone: 805 - 234 - 6220

Email: chasrhoads@sbcglobal.net



Drawing Status:  
**Contract Document**

Revision Summary:



Project:  
**New Dispatch Center  
Tulare County Sheriff & Fire  
5300 West Tulare Avenue  
Visalia, California**

Sheet Description:  
**Enlarged Lighting Control Plan**

Date: 8/8/2020  
Project: 19-700  
Scale: NOTED

Sheet No.: **E2.3**

Of x Sheets



**Chas Rhoads**  
 Architecture  
 Interiors  
 Landscape

128 Katherine Street - Hanford - California - 93230  
 Phone: 539 - 584 - 3371  
 Postal Box 221 - Morro Bay - California - 93443  
 Phone: 805 - 234 - 6220  
 Email: chasrhoads@sbcglobal.net



Drawing Status:  
**Contract Document**

Revision Summary:

NO.	DATE	DESCRIPTION

Project:  
**New Dispatch Center  
 Tulare County Sheriff & Fire  
 5300 West Tulare Avenue  
 Visalia, California**

Sheet Description:  
**Enlarged Lighting Plan &  
 Fixture Schedule**


Date: 8/8/2020  
 Project: 19-700  
 Scale: NOTED

Sheet No.: **E2.4**  
 Of x Sheets

**REFERENCE NOTES**

- REFER TO LIGHTING CONTROL PLANS FOR CONTROLLED RECEPTACLES CONTROLS FOR THIS ROOM.
- 1000W LIGHTING INVERTER, INV. (LVS #CEPS-A-1000)
- SUB-PANEL.
- NOT USED.
- PROVIDE LOW VOLTAGE CONNECTION TO WINDOW BLINDS PER MANUFACTURER INSTALLATION. REFER TO LIGHTING CONTROL PANELS FOR SWITCH CONTROL AND ADDITIONAL ACCESSORIES.
- EXTEND EXISTING BRANCH CIRCUIT TO NEW LIGHTS.

**DAYLIT ZONE LEGEND**




**LIGHTING ENLARGED PLAN AT RADIO ROOM [21]**  
 SCALE: 1/4" = 1'-0"

**LIGHTING FIXTURE SCHEDULE**


TYPE	MANUFACTURER	CATALOG NO.	VOLTAGE	MAX. VA.	LAMPING	MOUNTING	DESCRIPTION
A1	CREE INC	C TR B FP24 50L 40K WH	120	50	LED 40K	T-BAR CEILING	2'X4' LED FLAT PANEL 0-10V DIMMING
A2	CREE INC	C TR B FP22 40L 40K WH	120	40	LED 40K	T-BAR CEILING	2'X2' LED FLAT PANEL 0-10V DIMMING TO 10% WHITE FINISH
A3	LA LIGHTING	GHL320 40L 4L FSW PA1DRDM UNV 2 840	120	31.4	LED 40K	T-BAR CEILING	2'X2' LED FLAT PANEL 0-10V DIMMING TO 10%
B1	LA LIGHTING	GIC (2X4) 4 4L PDA DRDM UNV 2 840	120	28.5	LED 40K	T-BAR CEILING	2'X4' LED BASKET TROFFER 0-10V DIMMING TO 10% ALUMINIUM/SILVER FINISH
B2	LA LIGHTING	GIC (2X2) 4 2L PDA DRDM UNV 2 840	120	24.3	LED 40K	T-BAR CEILING	2'X2' LED BASKET TROFFER 0-10V DIMMING TO 10% ALUMINIUM/SILVER FINISH
C	CREE INC	C-STRIP A LIN4 43L 40K WH	120	38	LED 40K	STEP LIGHT	4' LINEAR STRIP LIGHT 0-10V DIMMING TO 10%
D	CREE INC	S DL6 15L 40K W/ S DLBT M SS C	120	15	LED 40K	SURFACE	6" SURFACE EXTERIOR DOWNLIGHT 0-10V DIMMING TO 10%
UC 1	CREATIVE SYSTEMS LIGHTING	(5)ECL-32" WH	120	120	LED 30K	UNDER CABINET	160" LED UNDERCABINET LIGHT
UC 2	CREATIVE SYSTEMS LIGHTING	(3)ECL-32" WH + (1)ECL-24	120	90	LED 30K	UNDER CABINET	120" LED UNDERCABINET LIGHT
UC 3	CREATIVE SYSTEMS LIGHTING	(3)ECL-32" WH + (1)ECL-16	120	84	LED 30K	UNDER CABINET	112" LED UNDERCABINET LIGHT
X	MOBERN LIGHTING	MEBELX W G W AC 1 2C	120	84	LED	CEILING	LED EDGE LIT EXIT SIGN WITH DUAL CIRCUIT OPTION. REFER TO CHEVRON DIRECTION ON PLANS
XM	COLE LIGHTING	L2600W 1 WHT FG 40K SC	120	9	LED	SURFACE	EMERGENCY LIGHTING.

**LIGHTING FIXTURE SCHEDULE NOTES**

- EXACT LOCATIONS: BEFORE CONSTRUCTION, VERIFY WITH ARCHITECT EXACT LOCATIONS AND MOUNTING HEIGHTS OF ALL LIGHT FIXTURES. SEE ARCHITECTURAL REFLECTED CEILING PLANS AND ELEVATIONS AS APPLICABLE.
- FIXTURE BRANCH CIRCUIT THROUGH-WIRING: VERIFY AND COMPLY WITH FIXTURE MANUFACTURER RESTRICTIONS AS DETERMINED BY UL & NEC.




**ENLARGED LIGHTING PLAN**  
 SCALE: 1/4" = 1'-0"



**Chas Rhoads**  
 Architecture  
 Interiors  
 Landscape

128 Katherine Street - Hanford - California - 93230  
 Phone: 539 - 584 - 3371  
 Postal Box 221 - Morro Bay - California - 93443  
 Phone: 805 - 234 - 6220  
 Email: chasrhoads@sbcglobal.net



Consultant:  
**Thoma Engineering**  
 THOMA ELECTRIC, INC.  
 P.O. Box 1167 - 3562 Empele St.  
 San Luis Obispo, CA 93406  
 Phone: (805) 543-3850  
 Fax: (805) 543-3829  
 cad@thomaelec.com


Drawing Status:  
**Contract Document**

Revision Summary:



Project:  
**New Dispatch Center  
 Tulare County Sheriff & Fire**  
 5300 West Tulare Avenue  
 Visalia, California

Sheet Description:  
**Partial Electrical Roof &  
 Grounding/Bonding Plans**

Date: 8/8/2020  
 Project: 19-700  
 Scale: NOTED  
 Sheet No.: **E3.1**  
 Of x Sheets



**2 GROUND/BONDING PLAN**  
 SCALE: 1/8" = 1'-0"



**1 PARTIAL ELECTRICAL ROOF PLAN**  
 SCALE: 1/8" = 1'-0"


**LIGHTNING PROTECTION**  
 PERFORMANCE SPECIFICATIONS

- PART 1 - GENERAL
- 1.1 SCOPE
- A. PROVIDE A COMPLETE LIGHTNING PROTECTION SYSTEM THAT CONFORMS TO UL780 FOR THE BUILDING. CONTRACTOR RESPONSIBLE FOR A COMPLETE/FUNCTIONAL SYSTEM, SHOW DRAWINGS WITH BUILDING OF MATERIALS, DETAILS, ETC.
  - B. THE LIGHTNING PROTECTION SYSTEM SHALL CONSIST OF AIR TERMINALS, ROOF CONDUCTORS, DOWN CONDUCTORS, GROUND CONNECTIONS, AND GROUNDS, ELECTRICALLY INTERCONNECTED TO FORM THE SHORTEST DISTANCE TO GROUND. ALL CONDUCTORS ON THE STRUCTURES SHALL BE EXPOSED EXCEPT WHERE CONDUCTORS ARE IN PROTECTIVE SLEEVES EXPOSED ON THE OUTSIDE WALLS. SECONDARY CONDUCTORS SHALL INTERCONNECT WITH GROUNDED METALLIC PARTS WITHIN THE BUILDING. INTERCONNECTIONS MADE WITHIN SIDE-FLASH DISTANCES SHALL BE AT OR ABOVE THE LEVEL OF THE GROUNDED METALLIC PARTS. ITEMS TO BE INTERCONNECTED INCLUDE METALLIC PARTS SUCH AS METAL DOORS, WINDOWS, AND GUTTERS.
  - C. ITEMS TO BE GROUNDED OR BONDED AS OCCURRING;
    1. STEEL FRAME BUILDINGS.
    2. RAMPS.
    3. TANKS AND TOWERS.
    4. METAL STACKS.
    5. NONMETALLIC STACKS.
    6. POST TENSIONING SYSTEMS.
    7. INTERCONNECTION OF METAL BODIES.
    8. FENCES.
    9. EXTERIOR OVERHEAD PIPE LINES.
    10. SEPARATELY MOUNTED SHIELDING SYSTEMS "MAST TYPE".
    11. SEPARATELY MOUNTED SHIELDING SYSTEMS "OVERHEAD GROUND-WIRE TYPE".
    12. METAL ROOFS.
    13. PARAPET (BACKSIDE) TIED TO STRUCTURAL STEEL REBAR AND SLAB.


- 1.2 REFERENCES
- A. THE PUBLICATIONS REFERENCED BELOW ESTABLISH MINIMUM REQUIREMENTS FOR MATERIALS, SYSTEMS AND EXECUTION THAT MAY BE SPECIFIED IN THIS SECTION.
    - NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)
    - NFPA 780 INSTALLATION OF LIGHTNING PROTECTION SYSTEMS
  - 1.3 SUBMITTALS
    - A. SHOP DRAWINGS.
    - B. CERTIFICATES OF COMPLIANCE.
- PART 2 - PRODUCTS
- 2.1 PRODUCTS
- A. NO COMBINATION OF MATERIALS SHALL BE USED THAT FORMS AN ELECTROLYTIC COUPLE OF SUCH NATURE THAT CORROSION IS ACCELERATED IN THE PRESENCE OF MOISTURE UNLESS MOISTURE IS PERMANENTLY EXCLUDED FROM THE JUNCTION OF SUCH METALS.
  - B. COPPER CONDUCTORS 375 POUNDS PER THOUSAND FEET AND MINIMUM SIZE WIRE NOT LESS THAN NO. 16 AWG.
  - C. COPPER CONDUCTOR RIBBON OR WEB MINIMUM SIZE OF NO. 10 AWG.
  - D. ALUMINUM STRIPS FOR MINIMUM SIZE OF NO. 12 AWG IN THICKNESS AND AT LEAST 1.5" WIDE.
  - E. GROUND RODS: MINIMUM SIZE OF 3/4" INCH IN DIAMETER AND 10 FEET IN LENGTH, COPPER CLAD STEEL.
  - F. CONNECTORS: CLAMP-TYPE CONNECTORS FOR SPLICING CONDUCTORS.

**REFERENCE NOTES**

1. WALL MOUNTED BUS BAR KIT INCLUDES 10"x1/4" COPPER GROUND BAR WITH TAPPED HOLES, INSULATORS, AND STAND-OFF BRACKETS.
2. WALL MOUNTED BUS BAR KIT INCLUDES 20"x1/4" COPPER GROUND BAR WITH TAPPED HOLES, INSULATORS, AND STAND-OFF BRACKETS.
3. PROVIDE #2 INSULATED GREEN JACKET BONDING CONNECTION TO RAISED FLOOR SUPPORT PEDESTAL. CONNECT TO PEDESTAL WITH UL LISTED GROUND CLAMP. GROUND ALL RAISE FLOOR PEDESTAL TOGETHER PER MANUFACTURER REQUIREMENTS.
4. REFER TO TIA/EIA J-STD-607-A FOR ADDITIONAL GROUNDING/BONDING REQUIREMENTS.
5. GROUND BAR AT IT ROOM.
6. GROUND BAR AT 2ND FLOOR RADIO ROOM.
7. LOCATION OF FOUR 4" CONDUIT WITH CABLE ACCESS WEATHERHEAD.
8. CABLE TRANSMISSION BRIDGE BY OTHERS.
9. PROSPECTIVE LOCATION OF 20 FT TOWER.
10. OUTLINE OF 2ND FLOOR RADIO ROOM.
11. 3/4"C (1) 3/0 THWN CU GROUND TO MSB GROUND BAR.
12. 3/4"C (1) 3/0 THWN GROUND BETWEEN ROOF GROUND BAR AND RADIO ROOM GROUND BAR.
13. 3/4"C (2) 3/0 THWN GROUND BETWEEN IT GROUND BAR AND RAISED FLOOR GROUND BAR.
14. PROVIDE #6 CU INSULATED GREEN JACKET GROUND CABLE. GROUND ALL METAL EQUIPMENT IN ROOM (I.E. DATA RACK, LADDER TRY, CONDUITS, METAL EQUIPMENTS, ETC.) PROVIDE APPROVED COMPRESSION CONNECTOR, TYPICAL.
15. STEP DOWN TRANSFORMER PER SINGE LINE DIAGRAM.
16. PER CEC 250.50 GROUNDING ELECTRODES PRESENT AT STRUCTURE.
17. VERIFY EXACT LOCATION OF GROUND BAR AT ROOF WITH OWNER'S VENDOR.



**7 TYPICAL SURFACE MTD. PANEL**  
SCALE: NTS



**4 TYPICAL SURFACE MTD. PANEL/CABINET**  
SCALE: NTS

# WARNING

## ARC FLASH HAZARD

<b>LINE SIDE of MAIN</b>	<b>FLASH PROTECTION BOUNDARY: 40 inches</b>
	<b>HAZARD RISK CATEGORY: CLASS 2</b>
	<b>INCIDENT ENERGY RANGE: 4 - 8 cal/cm<sup>2</sup></b>


<b>LINE SIDE of MAIN</b>	<b>FLASH PROTECTION BOUNDARY: 20 inches</b>
	<b>HAZARD RISK CATEGORY: CLASS 0</b>
	<b>INCIDENT ENERGY RANGE: 0 - 2 cal/cm<sup>2</sup></b>

PSE TQS#: #####      Date Issued: April 2004      Study Rev.: 0


LOCATION: BUS NAME      PROTECTIVE DEVICE: UPSTREAM DEVICE

NOTE:  
IN ACCORDANCE WITH CEC 110.16 PROVIDE ARC FLASH PROTECTION WARNING LABELS ON EACH SWITCHBOARD, PANELBOARD, AND TRANSFORMER. LABELS SHALL BE PER ANSI Z535.4 GUIDELINES PER THE ABOVE EXAMPLE.

**1 TYPICAL ARC FLASH SIGNAGE**  
SCALE:




**8 TYPICAL LAY-IN T-BAR FIXTURE FOR TROFFERS**  
SCALE: NTS




**5 RECESSED DOWNLIGHT MOUNTING**  
SCALE: NTS


**2 NOT USED**



**9 TYPICAL ROD/GROUND ACCESS WELL**  
SCALE: NTS



**6 TYPICAL DEVICE INSTALLATION - RATED WALLS**  
SCALE: NTS



**3 TYPICAL DEVICE ADA MOUNTING HEIGHTS**  
SCALE: NTS

128 Katherine Street - Hanford - California - 93230  
Phone: 539 - 584 - 3371  
Postal Box 221 - Morro Bay - California - 93443  
Phone: 805 - 234 - 6220  
Email: chasrhoads@sbcglobal.net

Professional Seal:  
  
EXPIRES: 08/30/21  
THOMA #19-8135

Consultant:  
**Thoma ENGINEERING**  
THOMA ELECTRIC, INC.  
P.O. Box 1167 - 3562 Empele St.  
San Luis Obispo, CA 93406  
Phone: (805) 543-3850  
Fax: (805) 543-3829  
cad@thomaelec.com

Drawing Status:  
**Contract Document**

Revision Summary:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_


Project:  
**New Dispatch Center  
Tulare County Sheriff & Fire**  
5300 West Tulare Avenue  
Visalia, California

Sheet Description:  
**Electrical Details**

Date: 8/8/2020  
Project: 19-700  
Scale: NOTED  
Sheet No.:

**E4.1**

Of x Sheets




**NOTES:**

1. CONTRACTOR MAY USE A CONDUIT SUSPENSION SYSTEM EQUIVALENT TO THAT WHICH IS DETAILED, HAVING THE FEATURES SHOWN AND APPROVED IN ADVANCE BY THE RESIDENT ENGINEER.
2. PROVIDE A SAMPLE SUPPORT SYSTEM TO KEEP ON JOB SITE FOR CONSTRUCTION GUIDE PURPOSES.
3. CONDUIT SUSPENSION SYSTEM SHALL BE INDEPENDENT OF ANY OTHER SUSPENSION SYSTEM.


**7 TYPICAL CONDUIT SUPPORT SYSTEM DETAIL**

SCALE:




**4 UPS MOUNTING DETAIL**

SCALE: NTS




**1 TYPICAL GROUND BAR DETAIL**

SCALE: NTS




**8 TRAFFIC RATED PULL BOX DETAIL**

SCALE:




**5 TRANSFORMER GROUNDING DETAIL**

SCALE: NTS




**2 GROUND/BOND CONNECTION AT RAISED FLOOR**

SCALE: NTS



**6 TRANSFORMER MOUNTING DETAIL**

SCALE: NTS




**3 FEEDER TRENCH DETAIL**

SCALE:

**Chas Rhoads**  
Architecture  
Interiors  
Landscape

128 Katherine Street - Hanford - California - 93230  
Phone: 539 - 584 - 3371  
Postal Box 221 - Morro Bay - California - 93443  
Phone: 805 - 234 - 6220  
Email: chasrhoads@sbcglobal.net



Consultant:  
**Thoma Engineering**  
THOMA ELECTRIC, INC.  
P.O. Box 1167 - 3562 Empeleo St.  
San Luis Obispo, CA 93406  
Phone: (805) 543-3850  
Fax: (805) 543-3829  
cad@thomaelec.com

Drawing Status:  
**Contract Document**

Revision Summary:

NO.	DESCRIPTION

Project:  
**New Dispatch Center  
Tulare County Sheriff & Fire**  
5300 West Tulare Avenue  
Visalia, California

Sheet Description:  
**Electrical Details**

Date: 8/8/2020  
Project: 19-700  
Scale: NOTED  
Sheet No.:

**E4.2**

Of x Sheets



STATE OF CALIFORNIA  
**Indoor Lighting**  
 NRCC-LTI-E (Rev. 06/17/18)  
 CERTIFICATE OF COMPLIANCE  
 Project Name: New Dispatch Center Tulare County Sheriff & Fire  
 Project Address: 5300 West Tulare Avenue  
 Report Page: Page 4 of 6  
 Date Prepared: 12/13/2019

**L. TAILORED METHOD GENERAL LIGHTING POWER ALLOWANCE**  
 This Section Does Not Apply

**M. ADDITIONAL LIGHTING ALLOWANCE: TAILORED SPECIAL FUNCTION AREAS**  
 This Section Does Not Apply

**N. ADDITIONAL LIGHTING ALLOWANCE: TAILORED WALL DISPLAY**  
 This Section Does Not Apply

**O. ADDITIONAL LIGHTING ALLOWANCE: TAILORED FLOOR AND TASK LIGHTING**  
 This Section Does Not Apply

**P. ADDITIONAL LIGHTING ALLOWANCE: TAILORED ORNAMENTAL/SPECIAL EFFECTS**  
 This Section Does Not Apply

**Q. ADDITIONAL LIGHTING ALLOWANCE: TAILORED VERY VALUABLE MERCHANDISE**  
 This Section Does Not Apply

**R. POWER ADJUSTMENT: LIGHTING CONTROL CREDIT (PAF)**  
 This Section Does Not Apply

**S. RATED POWER REDUCTION COMPLIANCE BY SPACE**  
 This Section Does Not Apply

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance: <http://www.energy.ca.gov/09024/2016standards> July 2018

STATE OF CALIFORNIA  
**Indoor Lighting**  
 NRCC-LTI-E (Rev. 06/17/18)  
 CERTIFICATE OF COMPLIANCE  
 Project Name: New Dispatch Center Tulare County Sheriff & Fire  
 Project Address: 5300 West Tulare Avenue  
 Report Page: Page 5 of 6  
 Date Prepared: 12/13/2019

**T. DECLARATION OF REQUIRED CERTIFICATES OF INSTALLATION**  
 Table Instructions: Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP). For more information visit: <https://www.energy.ca.gov/09024/2016standards/0333/acceptance-test-technician-certification-provider>

YES	NO	Form/Title	Field Inspector	
			Pass Fail	
<input checked="" type="radio"/>	<input type="radio"/>	NRCC-LTI-03-E - Must be submitted for all buildings.	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="radio"/>	<input type="radio"/>	NRCC-LTI-02-E - Must be submitted for a lighting control system, or for an Energy Management Control System (EMCS), to be recognized for compliance.	<input type="checkbox"/>	<input type="checkbox"/>
<input type="radio"/>	<input checked="" type="radio"/>	NRCC-LTI-03-E - Must be submitted for a line-voltage track lighting integral current limiter, or for a supplementary overcurrent protection panel used to energize only line-voltage track lighting, to be recognized for compliance.	<input type="checkbox"/>	<input type="checkbox"/>
<input type="radio"/>	<input checked="" type="radio"/>	NRCC-LTI-04-E - Must be submitted for two interlocked systems serving an auditorium, a convention center, a conference room, a multipurpose room, or a theater to be recognized for compliance.	<input type="checkbox"/>	<input type="checkbox"/>
<input type="radio"/>	<input checked="" type="radio"/>	NRCC-LTI-05-E - Must be submitted for a Power Adjustment Factor (PAF) to be recognized for compliance.	<input type="checkbox"/>	<input type="checkbox"/>
<input type="radio"/>	<input checked="" type="radio"/>	NRCC-LTI-06-E - Must be submitted for additional wattage installed in a video conferencing studio to be recognized for compliance.	<input type="checkbox"/>	<input type="checkbox"/>

**U. DECLARATION OF REQUIRED CERTIFICATES OF ACCEPTANCE**  
 Table Instructions: Selections have been made based on information provided in previous tables of this document. If any selection needs to be changed, please explain why in Table E. Additional Remarks. These documents must be provided to the building inspector during construction and must be completed through an Acceptance Test Technician Certification Provider (ATTCP). For more information visit: <https://www.energy.ca.gov/09024/2016standards/0333/acceptance-test-technician-certification-provider>

YES	NO	Form/Title	Field Inspector	
			Pass Fail	
<input checked="" type="radio"/>	<input type="radio"/>	NRCC-LTI-02-A - Must be submitted for occupancy sensors and automatic time switch controls.	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="radio"/>	<input type="radio"/>	NRCC-LTI-03-A - Must be submitted for automatic daylight controls.	<input type="checkbox"/>	<input type="checkbox"/>
<input type="radio"/>	<input checked="" type="radio"/>	NRCC-LTI-04-A - Must be submitted for demand responsive lighting controls.	<input type="checkbox"/>	<input type="checkbox"/>
<input type="radio"/>	<input checked="" type="radio"/>	NRCC-LTI-05-A - Must be submitted for institutional tuning power adjustment factor (PAF).	<input type="checkbox"/>	<input type="checkbox"/>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance: <http://www.energy.ca.gov/09024/2016standards> July 2018

STATE OF CALIFORNIA  
**Indoor Lighting**  
 NRCC-LTI-E (Rev. 06/17/18)  
 CERTIFICATE OF COMPLIANCE  
 Project Name: New Dispatch Center Tulare County Sheriff & Fire  
 Project Address: 5300 West Tulare Avenue  
 Report Page: Page 6 of 6  
 Date Prepared: 12/13/2019

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**  
 Documentation Author Name: William Thoma  
 Company: Thoma Electric, Inc.  
 Address: 3582 Empleo, Suite C  
 City/State/Zip: San Luis Obispo, CA 93401  
 Documentation Author Signature: [Signature]  
 Signature Date: 12/13/2019  
 CEA/HERS Certification Identification (if applicable): E10757  
 Phone: 805-543-3850

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**  
 I certify the following under penalty of perjury, under the laws of the State of California:  
 1. The information provided on this Certificate of Compliance is true and correct.  
 2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).  
 3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.  
 4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.  
 5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.  
 Responsible Designer Name: William Thoma  
 Company: Thoma Electric, Inc.  
 Address: 3582 Empleo, Suite C  
 City/State/Zip: San Luis Obispo, CA 93401  
 Responsible Designer Signature: [Signature]  
 Date Signed: 12/13/2019  
 License: E10757  
 Phone: 805-543-3850

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance: <http://www.energy.ca.gov/09024/2016standards> July 2018

STATE OF CALIFORNIA  
**Indoor Lighting**  
 NRCC-LTI-E (Rev. 06/17/18)  
 CERTIFICATE OF COMPLIANCE  
 Project Name: New Dispatch Center Tulare County Sheriff & Fire  
 Project Address: 5300 West Tulare Avenue  
 Report Page: Page 1 of 6  
 Date Prepared: 12/13/2019

**A. GENERAL INFORMATION**

01 Project Location (city)	Visalia	04 Total Conditioned Floor Area (ft <sup>2</sup> )	3,934
02 Climate Zone	13	05 Total Unconditioned Floor Area (ft <sup>2</sup> )	0
03 Occupancy Types Within Project (select all that apply): <input type="checkbox"/> Office <input type="checkbox"/> Retail <input type="checkbox"/> Warehouse <input type="checkbox"/> High Rise Residential <input type="checkbox"/> Relocatable <input checked="" type="checkbox"/> Other (write in):	06 # of Stories (Habitable-Above Grade)	07 # of Stories (Habitable-Below Grade)	1

**B. PROJECT SCOPE**  
 Table Instructions: Include any lighting systems that are within the scope of the permit application and are demonstrating compliance using the prescriptive path outlined in §140.5 or §142.10(a) for alterations. **WARNING:** Changing the Calculation Method in this table will result in the deletion of data previously input. If you need to change the calculation method, please open a new form or use "Save As".

Scope of Work	Conditioned Spaces	Unconditioned Spaces
01	02	03
My Project Consists of (check all that apply):	Calculation Method	Area (ft <sup>2</sup> )
<input type="checkbox"/> New Lighting System		
<input checked="" type="checkbox"/> Altered Lighting System	Area Category	3,934
	Area Category	0
<b>Total Area of Work (ft<sup>2</sup>)</b>		<b>3,934</b>

**C. COMPLIANCE RESULTS**  
 Table Instructions: If any cell on this table says "DOES NOT COMPLY" or "COMPLIES WITH EXCEPTIONAL CONDITIONS" refer to Table O, for guidance.

Lighting in Unconditioned and Unconditioned Spaces Must Not Be Combined for Compliance per §140.6(b)(1)	Allowed Lighting Power per §140.6(d) (Watts)					Actual Lighting Power per §140.6(e) (Watts)					Compliance Results
	01	02	03	04	05	06	07	08	09	10	
	Complete Building Category §140.6(c)(1)	Area Category Footcandles §140.6(c)(2)	Area Category Footcandles §140.6(c)(3)	Tailored Footcandles §140.6(c)(4)	Total Allowed (Watts)	Total Designated (Watts)	Portable Lighting §140.6(a)(2)	PAF Control Credits §140.6(a)(2)	Total Actual (Watts)	§140.6(b)(2) Must be ≥ 0.9 §140.6	
	(See Table I)	(See Table J)	(See Table K)	(See Table L)	3,540.6	2,458.5			2,458.5	COMPLIES	
	<b>Controls Compliance (See Table H for Details)</b>					<b>COMPLIES</b>					
	<b>Rated Power Reduction Compliance (See Table S for Details)</b>					<b>Not Applicable</b>					

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance: <http://www.energy.ca.gov/09024/2016standards> July 2018

STATE OF CALIFORNIA  
**Indoor Lighting**  
 NRCC-LTI-E (Rev. 06/17/18)  
 CERTIFICATE OF COMPLIANCE  
 Project Name: New Dispatch Center Tulare County Sheriff & Fire  
 Project Address: 5300 West Tulare Avenue  
 Report Page: Page 2 of 6  
 Date Prepared: 12/13/2019

**D. EXCEPTIONAL CONDITIONS**  
 This table is auto-filled with uneditable comments because of selections made or data entered in tables throughout the form.  
 No exceptional conditions apply to this project.

**E. ADDITIONAL REMARKS**  
 This table includes remarks made by the permit applicant to the Authority Having Jurisdiction.

**F. INDOOR LIGHTING FIXTURE SCHEDULE**  
 Table Instructions: Include all permanent designed lighting and all portable lighting in offices.

01	02	03	04	05	06	07	08	09
Name or Item Tag	Complete Luminaire Description	Specialized Luminaire Types	Watts per luminaire <sup>1</sup>	How Wattage is determined	Total number luminaires	Exempt per §140.6(a)(3)	Design WATTS	Field Inspector
		Track	Portable					Pass Fail
A1	A1	<input type="checkbox"/>	<input type="checkbox"/>	50 Mfr. Spec <sup>2</sup>	3	<input type="checkbox"/>	150	<input type="checkbox"/>
A2	A2	<input type="checkbox"/>	<input type="checkbox"/>	40 Mfr. Spec <sup>2</sup>	16	<input type="checkbox"/>	640	<input type="checkbox"/>
A3	A3	<input type="checkbox"/>	<input type="checkbox"/>	31.4 Mfr. Spec <sup>2</sup>	2	<input type="checkbox"/>	62.8	<input type="checkbox"/>
B1	B1	<input type="checkbox"/>	<input type="checkbox"/>	28.5 Mfr. Spec <sup>2</sup>	32	<input type="checkbox"/>	912	<input type="checkbox"/>
B2	B2	<input type="checkbox"/>	<input type="checkbox"/>	24.3 Mfr. Spec <sup>2</sup>	9	<input type="checkbox"/>	218.7	<input type="checkbox"/>
C	C	<input type="checkbox"/>	<input type="checkbox"/>	38 Mfr. Spec <sup>2</sup>	2	<input type="checkbox"/>	76	<input type="checkbox"/>
D	D	<input type="checkbox"/>	<input type="checkbox"/>	15 Mfr. Spec <sup>2</sup>	1	<input type="checkbox"/>	15	<input type="checkbox"/>
UC1	UC1	<input type="checkbox"/>	<input type="checkbox"/>	120 Mfr. Spec <sup>2</sup>	1	<input type="checkbox"/>	120	<input type="checkbox"/>
UC2	UC2	<input type="checkbox"/>	<input type="checkbox"/>	90 Mfr. Spec <sup>2</sup>	2	<input type="checkbox"/>	180	<input type="checkbox"/>
UC3	UC3	<input type="checkbox"/>	<input type="checkbox"/>	84 Mfr. Spec <sup>2</sup>	1	<input type="checkbox"/>	84	<input type="checkbox"/>
<b>Total Designed Watts CONDITIONED SPACES:</b>							<b>2,458.5</b>	

**NOTES:** Authority Having Jurisdiction may ask for Luminaire cut sheets to confirm wattage used for compliance per §140.6(c). Wattage used must be the maximum rated for the luminaire, not the lamp.

**G. TRACK LIGHTING**  
 This Section Does Not Apply

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance: <http://www.energy.ca.gov/09024/2016standards> July 2018

STATE OF CALIFORNIA  
**Indoor Lighting**  
 NRCC-LTI-E (Rev. 06/17/18)  
 CERTIFICATE OF COMPLIANCE  
 Project Name: New Dispatch Center Tulare County Sheriff & Fire  
 Project Address: 5300 West Tulare Avenue  
 Report Page: Page 3 of 6  
 Date Prepared: 12/13/2019

**H. INDOOR LIGHTING CONTROLS (Not Including PAFs)**  
 Table Instructions: Please include lighting controls for conditioned and unconditioned spaces in this table. When an option having a "1" is selected, the notes section of this table must be completed. The lighting controls section of the Compliance Summary Table on the first page will show "DOES NOT COMPLY" if the notes are left blank.

Area Level Controls	Building Level Controls								
	01	02	03						
	Mandatory Demand Response §130.1(a)	Shut-off Controls §130.1(c)	Field Inspector						
	Not Required < 10,000 SF	See Area Level Controls	Pass Fail						
04	05	06	07	08	09	10	11	12	
Area Description	Complete Building or Area Category Primary Function Area	Area Controls §130.1(a)	Multi-Level Controls §130.1(b)	Shut-Off Controls §130.1(c)	Primary/Skyline Daylighting §130.1(d)	Secondary Daylighting §130.1(d)	Interlocked Daylighting Systems §130.1(d)	Field Inspector	
see lighting & lighting control plans	Police/Fire Station	Manual ON/OFF	Dimmer	Occ Sensor	Included	Included	<input type="checkbox"/>	<input type="checkbox"/>	
*NOTES: Controls with a "1" require a note in the space below explaining how compliance is achieved. Ex: Conference 1: Primary/Skyline Daylighting. Exempt because less than 120 watts of general lighting. EXCEPTION 1 to §130.1(d):								13	
								Plan Sheet Showing Daylit Zones:	


**I. LIGHTING POWER ALLOWANCE: COMPLETE BUILDING OR AREA CATEGORY METHODS**  
 Table Instructions: Complete the table for each area complying using the Complete Building or Area Category Methods per §140.6(d). Indicate if additional lighting power allowances per §140.6(c)(1) or adjustments per §140.6(a) are being used.

Conditioned Spaces	Additional Allowances / Adjustments					
	01	02	03	04	05	06
Area Description	Complete Building or Area Category Primary Function Area	Allowed Density (W/ft <sup>2</sup> )	Area (ft <sup>2</sup> )	Allowed Wattage (Watts)	Footnotes	PAF
Police/Fire Station	Low Bay Comm/Industrial	0.9	3,934	3,540.6		<input type="checkbox"/>
<b>TOTAL:</b>				<b>3,934</b>	<b>3,540.6</b>	See Tables J, K, R for detail

**J. POWER ADJUSTMENT: PORTABLE LIGHTING IN OFFICES**  
 This Section Does Not Apply


**K. ADDITIONAL LIGHTING ALLOWANCE: AREA CATEGORY METHOD FOOTNOTES**  
 This Section Does Not Apply

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance: <http://www.energy.ca.gov/09024/2016standards> July 2018



**Chas Rhoads**  
 Architecture  
 Interiors  
 Landscape

128 Katherine Street - Hanford - California - 93230  
 Phone: 559 - 584 - 3371  
 Postal Box 221 - Morro Bay - California - 93443  
 Phone: 805 - 234 - 6220  
 Email: chasrhoads@srbglobal.net



Consultant:  
**Thoma Engineering**  
 THOMA ELECTRIC, INC.  
 P.O. Box 1167 - 3602 Empleo St.  
 San Luis Obispo, CA 93406  
 Phone: (805) 543-3850  
 Fax: (805) 543-3829  
 cad@thomalec.com

Drawing Status:  
**Contract Document**

Revision Summary:

Project:  
**New Dispatch Center**  
**Tulare County Sheriff & Fire**  
**5300 West Tulare Avenue**  
**Visalia, California**

Sheet Description:  
**Lighting Energy Compliance**  
**Forms**

Date: 8/8/2020  
 Project: 19-700  
 Scale: NOTED  
 Sheet No.: **E5.1**  
 Of x Sheets