


Chas Rhoads
Architecture
Interiors
Landscape

128 Katherine Street - Hanford - California - 93230
Phone: 559 - 584 - 3371
Postal Box 221 - Morro Bay - California - 93443
Phone: 805 - 234 - 6220
Email: chasrhoads@sbcglobal.net



Consultant:

Drawing Status:
Contract Document
Revision Summary:

Project:
**New Dispatch Center
Tulare County Sheriff & Fire
5300 West Tulare Avenue
Visalia, California**
Sheet Description:
**Fire Suppression
Requirements**

Date: 08/08/20
Project: 19-700
Scale: 1/4" = 1'
Sheet No.: **FS1**
OF 1 Sheet

PROJECT DATA		
AREA	HAZARD	MAX. SPACING
WORK AREAS	LIGHT	225 S.F.




**SCOPE OF WORK
SPRINKLERS**

ATTACH TO EXISTING BRANCH LINES AND/OR EXISTING OUTLETS AND INSTALL NEW PENDENT SPRINKLERS THROUGHOUT THE CEILING AS SHOWN

ALL NEW PENDENT SPRINKLERS TO BE CHROME QUICK RESPONSE SEMI-RECESSED

ALL HEADS TO BE PLACED CENTER OF TILE OR SYMMETICAL WITH OTHER CEILING FIXTURES

HANGERS TO BE USED



FIRE SUPPRESSION PLAN

SCALE: 1/4" = 1'-0"

**SCOPE OF WORK
CLEAN AGENT SYSTEM**

THE DATA AND ELECTRICAL ROOM IN HATCHED AREA SHALL BE PROTECTED BY A NEW 'TOTAL FLOOD' CLEAN AGENT SYSTEM COMPLETE AND FULLY APPROVED AND OPERATIONAL - NO WET SPRINKLERS IN THIS AREA

